Reference: Index Sr. NO 30 SITE INSPECTION REPORT

SHEINGLEHEE

(Prescribed vide PCCF (HOFF) No Desk – 17 - 4 / 1445. Dated 5/11/2015)

Sr	(Prescribed vide PCCF (HOFF) No De Sr. Items			Observations and remarks.						
No	Items									
				Proposal for diversion of forest land from gut no 191						
1	Name of Project and location			Comp. no 151, at Solashi, Tal Koregaon, & G. no						
	(Range, Round Beat)									
			1010/1,Comp. no 36 at Village Vele, Tal. – Wai, Dist.							
			Satara, for laying of overground 440 volt L.T. Aerial							
			Bunched Cable twisted electric line (Insulated cable)							
				for Hareshwer Temple at Solashi, & Dhareshwer						
				Temple at Vele, Tal. Wai , Dist Satara , under DPDC						
				Scheme.415 Proposal under section 2(ii) of Forest						
				Conservation Act, 1980.						
			Range		Round		Beat			
				Koregaon		Wathar		Rand	ullabad	
				Wai			Bhuij		Bhop	egaon
2	Name of User Agency Deputy Ex. Engineer , M. S. E. D.C. Ltd. Sub-divisi				-division					
-		0	Wathar , At/post Wather Station, Tal. Koreg							
				Dist. – Satara. Pin -415 524						
3	Date of sit	e Inspection								
4	Extent (ha)	and legal status	tus of Forest land Required 0.64 ha. legal status of Forest							
	forest la	nd proposed	to	land. is Reserved Forest.						
	diversion.									
5	a) Details of	Name of Village	Fo	prest land Required						
	forest land proposed		Gu	t No	Comp.	LX V	V. in Mt	Area in	Sta	atus
	for	Calash!	10	1		157		Ha.		c .
	diversion and activity-	Solashi Tal Koregaon	19:	L	151	1579	5 X 4	0.6300	R.	
	wise break-				L					

.

	up of Forest Vele, Tal Wai 10	010/1 36 25 x 4 0.01 R P				
	land. b)Density Tctal forest land requi	lred 0.64				
	and Eco-	0.57.700/				
	value class Eco-Value class = Op	en Forest, Eco-Class III. NPV Levy = 9,57,780/				
6	Whether the requirement of	Yes, the requirement of forest land as proposed by				
	forest land as proposed by the	the User Agency is unavoidable and barest minimum				
	User Agency in col. of Part I is unavoidable and barest minimum	for the project also proposed work will be along the				
	for the project. If no	existing footpath, which is sanction rights & privileges				
	recommended area item-wise	of local peoples Hence three alternatives has not				
	with details of alternative	examined.				
	examined.					
7	Whether the proposal involves					
	any construction of	construction.				
	building(including residential) or					
	not? If Yes , details thereof					
8	a) whether forest area proposed	Forest area Proposed for diversion is not importance				
	for diversion is important form	from Wildlife point of view.				
	wildlife point of view or not.					
	b) Details of any rare or endangered or unique species of	There is no any rare or endangered unique species of flora and fauna found in proposed forest land.				
	flora and fauna found in					
	proposed forest land. If so the					
	details thereof.	The second former land subside Coloredai Tigon				
	c) Aerial distance from the	recorved The work will be about 135 Km from				
	nearest boundary of any	boundary of Sahyadri Tiger reserved				
	Protected Area (Km). d) Remarks about sensitivity of					
	the forest area likely to be	There is no adverse effect due to this project as project is laying of overground Aerial Bunched Cable twisted				
	affected due to project.	electric cable				
	e) Whether wildlife mitigation					
	plan is required? If yes, reasons	, No				
	therefor.					
9	Details of vegetation:	No tree felling is required.				
	a) I otal no of trees to be felled.					

	b) Number of trees to be felled of	nil				
	girth below 60 cm.	nil				
	c) Number of trees to be felled of girth above 60 cm.					
	d) Effect of removal of trees on the general ecosystem in the	nil				
area.		Question doesn't arise.				
10	Background note on the proposal (short summary)	Village Solashi is situated in TalKoregaon, DistSatara				
		, there are two historical temple situated on small				
		hillock named as Harihareshwer Temple & Dhareshwer				
		Temple. The Forest settlement officer had inquired the				
		rights & privileges .of local villages in which the right				
		of approach foot path Human & Animal towers				
		Hareshwer Temple & Dhareshwer temple had been				
		approved. under Indian Forest Act 1927. The proposed				
		work is within forest land. In this project the Aerial				
		Bunched Cable twisted cable (Insulated cable) will				
		be used for reducing with of .Right of Way (Row) of				
		transmission line in forest area. Which also reduce				
		accident of forest fire due to electric line , & to prevent				
		death of wild animal & birds.				
		In this project there is no need of felling of trees This				
		project has been sanctioned by Satara District Plan				
		2021-22 and about 9.00lakh has been made available				
		for laying of overground 440-volt AB cable. The				
		implementation and maintenance of this line will be				
		done by M.S.EDC Ltd. Wither Station				
11	Whether the proposal involves	No				
	any violation of Forest	No Violation has been done by P.A.				
	(Conservation) Act, 1980? If yes,					

	a detailed report on violation	
	including action taken against the	
	concerned officials to be	
	attached	
12	Whether the proposal involves	No involves rehibitions of displaced nerves
	rehibitions of displaced person, If	No involves rehibitions of displaced person
	yes, whether rehibitions plan has	
	approved by the State Govt.?	
13	Details of catchment and	Not applicable.
	culturable command area under	
	the project (If applicable)	
	Status of catchment area	
	treatment plan to prevent	Not applicable.
	siltation of reservoir (If	
	applicable)	
14	Utility of Project	This project is for public use visiting temple of
14	other of Project	This project is for public use visiting temple of
		Hareshwar & Dhupeshwar Temple , Gram Devata of
		village Solashi, Tal. Koregaon, DistSatara
15	Whether land being diverted has	Nσ.
	any socio-cultural/ religious	
	values? Whether any scared	
	grove or very old growth tree/	No.
	forests exist in the areas	
	proposed for diversion	

16	A				······		
10	Any other	In this project as per Central Govt. Guidelines Para 10.1 for lay					
	importance	overhead electric line	c lines fulfils the following conditions				
	information	Transmission Voltage	Width of	Width	Minimum clearance		
	related to the		Right of way	ay between two	between Con. & tress		
	project (separate	4		conductors			
	note may be	11 Kv Standard Nor	ns 7 mt.	Not	2.6 mt		
	attached , If	(10.1)		required			
	required)	440-Volt Insulat	ed Not	Not	Not applicable as		
		cable	applicable	Require	insulted Cable is used		
					(Aerial Bunched		
					Cable twisted cable)		
17	Details of docu	iments and 1) A	blication Of Gram panchayat Solashi				
	photographs enclos	ed 2) Ce	2) Central Govt. Guideline for NPV (3) Sanction of				
		DF	DPDC Fund (4) Photographs of proposed area.				
18	Recommendation	of the The p	The proposal is recommended for acceptance,				
	Inspecting Officer.						

Place --Satara .

Date / /2022

(M. N Mohite) Deputy Conservator of Forests, Forest Division, Satara,