

**RECOMMENDATION REPORT OF THE PROPOSED PROJECT ON KSEB , PATTIKKAD
ELECTRICAL SECTION , THRISSUR.**

Inspected the proposed site with Range Forest Officer, Pattikkad and field staff on 01.02.2017. The proposed site is located at Variyathcaud area in Pattikkad Reserve Forest.

In connection with total electrification scheme of State Government, for giving power supply to two applicants at Variyathcaud area, 222 m length Underground cable has to be drawn through Reserve Forest. The work involved to construct the line is digging a trench of 50 cm width and 1 m depth, laying the cable and backfilling the trench.

The underground cable sought to be laid along an existing fire line, and is about 222 m length, 50cm width and 1 m depth (Total area 0.0111 Ha) through the forest land to the colony. No tree felling is required to execute the work, and the proposed work does not hamper in any way the flora & fauna of the region. I am therefore of the view that the project may be accorded permission to operate.


Chief Conservator of Forests
Central Circle, Thrissur.

PART –III

(TO BE FILLED BY CONCERNED CHIEF CONSERVATOR OF FORESTS)

14	Whether site, where the forest land involved is located has been inspected by concerned Conservator of Forests (Yes/No). If yes, the date of inspection notes to be enclosed.	Inspected the site on 01.02.2017. Inspection note enclosed.
15	Whether the concerned Conservator of Forests agree with the information given in Part-B and the recommendations of Deputy Conservator of Forests	Agreed as stated in the inspection note of the undersigned
16	Specific recommendation of concerned Conservator of Forests for acceptance or otherwise of the proposal with detailed reasons.	Recommended. Report enclosed.

Signature :

Name : Rajesh Ravindran, IFS

Office Seal :

