

To

The Chief Manager, POWER GRID,
Power Grid Corporation of India Limited,
139, Sec-1, Urban Estate, Ambala City,
Haryana-134003.

Memo No. 9320

Dated: 16/6/15

Subject:- Regarding No Objection Certificate (NOC) for Construction of 400 KV D/C Panchkula-Patiala Transmission Line.

Ref.: Your memo no. N2PTL/PPTL/2014/13 dated 15.12.2014 on the above noted subject.

It has been reported by SDE, PSD-II, Hr. PWD B&R, Panchkula has informed that the 5 roads were got inspected by your officers to Sh. Harpreet Singh, Junior Engineer, of this office on 8.5.2015 as per details given below:

Sr. No.	Name of road	Height from the ground level to Ist crossing / arm of electrical towers informed.
1.	Sangrana Bhareli road	22.20 Mtr. Height
2.	Jeetpur road	26.20 Mtr. Height
3.	Derabassi Barwala Road	19.00 Mtr. Height
4.	Barwala to Kammi road	26.30 Mtr. Height
5.	Kammi to Sultanpur road	29.20 Mtr. Height

In view of IRC 32-1969, this office has no objection if the height from the ground as mentioned above is maintained. It is however made clear that if the above height is not maintained then this no objection ^(NOC) shall stands cancelled automatically.

DA/Nil.

Executive Engineer,
Provl. Divn.Hr., PWD B&R,
Panchkula

Endst No.

Dated:

A copy is forwarded to Sub Divisional Engineer, Provl. Sub Division No. II Hr. PWD B&R Br. Panchkula w.r.t. his memo no. 1381 dated 15.05.2015 for information.

Executive Engineer,
Provl. Divn.Hr., PWD B&R,
Panchkula