

Government of Jammu & Kashmir
OFFICE OF THE EXECUTIVE ENGINEER JAL SHAKTI (PHE) DIVISION KUPWARA

The Divisional Forest Officer,
Kamraj Forest Division
Zangli Kupwara

No. PHEDK/
Date:

2545-48
13-10-21

Subject: Proposal No. FP/JK/WATER/143900/2021; Dated: 23/06/2021, regarding NOC for Water Supply Scheme (WSS) Palnard Chandigam


Sir,

Please refer CCF Kashmir North Circle Sopore Letter No. FD/CFN/FCA/2021-22/1075-76; Dated 09/10/21. In this regard the following clarification against the EDS raised by the Govt. of Jammu & Kashmir is submitted as under.

S.No	EDS	Reply
1.	That the exemption from paying NPV is given for drinking water pipelines of 4" diameter. In this particular case, width of land required for supply mains is mentioned as 0.50 m. Please clarify whether the exemption from payment of NPV is valid for this case also.	The nominal diameter of the supply mains in this case is 50 mm (2 inches), however, in case of pipelines to be laid underground, the width of excavated trench is always kept greater than the diameter of the pipeline to allow for the working space during laying and fitting of the pipeline & for placing the pipeline sufficiently deep from ground level in order to protect it from frost action during the winter. The whole width of the trench up to 0.50 m excavated will be backfilled to NSL leaving the pipeline completely underground in future.

In view of the above, it is requested to process the subject case for seeking approval of the competent authority for diversion of the forest land at the earliest.

Yours faithfully,


Executive Engineer
PHE Jal Shakti
Division Kupwara

Copy to the:

1. Chief Engineer Jal Shakti PHE Department Kashmir for favour of kind information
2. District Development Commissioner, Kupwara for information
3. District Superintending Engineer, Hydraulic Circle Kupwara, H/Q Handwara for information.
4. File Concerned