



कार्यालय विद्युत भवन ज्योति नगर, जयपुर 302006  
[कॉर्पोरेट पहचान संख्या (सीआईएन):U40109RJ2000SGC016485]

कार्यालय अधिशाषी अभियन्ता ( टी. एण्ड सी.)  
राजस्थान राज्य विद्युत प्रसारण निगम लिमिटेड, सीकर

फतेहपुर रोड, सबलपुरा, सीकर - 332001 दूरभाष नं० 01572 - 272002

ईमेल आईडी : [xen.tnc.sikar@rvpn.co.in](mailto:xen.tnc.sikar@rvpn.co.in); वेबसाइट: [www.rvpn.co.in](http://www.rvpn.co.in)

क्रमांक/रा.रा.वि.प्र.नि./ अधि. अभि. (टी.एण्ड सी.) सीकर/संस्थापन/प्रे. दिनांक

निमित्त:-

उप वन संरक्षक,  
सीकर।

विषय:- Diversion of 3.9836 ha. forest land for proposed uprating of transmission line to enhance the capacity of existing 132 KV S/C line from 132 KV GSS Sanwali road water works 132 KV GSS Ranoli by dismantling the existing line.

- संदर्भ:- 1. पत्र क्रमांक 8बी/राज/C4/27/2020/एफसी/788  
2. पत्र क्रमांक: एफ ( )एफसीए/उवसंसी/2020-21/8415 दिनांक 30.09.2020.

महोदय,

उपरोक्त विषयान्तर्गत निवेदन है कि उक्त प्रस्ताव में आप के ईओडीएसओ - के क्रम में चाही गई सूचना निम्नानुसार है:-

Sr.No	Essential Details Sought	Compliance
1	Another proposal for uprating work of 132 KV D/C line from 220 KV GSS Sikar to 132 KV GSS Sanwali road Water works for diversion of 5.5401 ha. of forest land is received in this office. While administrative and financial approval for both the work is same. Why the two proposals were not submitted as consolidated proposal?	The administrative and financial approval is for complete scheme which comprises three separate projects of uprating of lines which feed different Grid Sub Stations. Both the works are entirely different as 220kV GSS Sikar - Sanwali Road line is double Circuit line whereas Sanwali Road- Ranoli is Single Circuit line. Both works are being executed separately through work orders awarded to different Contractors.
2	When was the existing H-Pole line constructed? Detail need to be provided and supporting documents are required.	H-Pole line was constructed in 1965 as Ratangragh-Jaipur line, which divided in many parts with different names during course of time. The 132 KV line from 220 KV GSS Sikar to 132 KV GSS Sanwali Road water works is a part of line.
3	NOC of concerned departments need to be provided.	NoC from PHED Deptt is hereby enclosed and there is no involvement of other Deptt like NHAI, Railway etc.
4	List of tree to be actual felled needs to be provided separately.	As the line is already in service and maintaining proper clearance, So number of trees to be actually felled is nil.
5.	As per Working Plan. The area falls under Wildlife Management Working Circle. Hence comments of CWLW are required.	Process for seeking comments of CWLW is in process.
6.	As per GIS DSS analysis the area proposed for diversion is 4.01 ha. Instead pf 3.9836 ha. This needs to clarified.	The Area proposed to be diverted was finalized at the Nodal level with available software. Deviation may be due to Superior level of accuracy of GIS DSS.

अतः निवेदन है कि प्रकरण में नियमानुसार कार्यवाही कर सैद्धान्तिक स्वीकृति दिलवाने की कृपा करें।

संलग्न:- उपरोक्तानुसार

(J. P. Khichar)  
Executive Engineer (T&C)  
R.R.V.P.N.L., Sikar

अधिशाषी अभियन्ता ( टी. एण्ड सी.)  
रा.रा. वि. प्र. नि. लि. सीकर।