


**DIRECTORATE OF ENERGY**  
**GOVERNMENT OF HIMACHAL PRADESH**  
**SHANTI BHAWAN, PHASE-III, SEC-6, NEW SHIMLA-171009**  
**Tel No. 0177-2673976, Fax No. 2673553, Email: ceenergy09@gmail.com**

**CORRIGENDUM**

In partial modification to the Office Order issued by this office and endorsed vide No DoE / CE (TEC) / - Hamshu- I (R) / 2016-853-61 dated 02/5/2016 vide which revised Techno Economic Clearance (TEC) of Hamshu-I SHP (2.00 MW) in District Kullu (HP) was accorded, the evacuation proposal of Hamshu-I SHP (2.00 MW) appearing at Clause 2 (xviii) may now be read as under:

**“For evacuation of power the IPP shall interface this project with 33 / 220 kV pooling station planned at Fozal in joint mode with Pharari SHP at 33 kV level by laying 33 kV underground cable. ”**


All others terms and conditions of Techno Economic Clearance (TEC) issued vide Office Order endorsed vide No DoE/CE(TEC)/ - Hamshu-I (R) / 2016-853-61 dated 02/5/2016 shall remain the same.

  
**Chief Engineer, 24/11/17**  
**Directorate of Energy,**  
**New Shimla-171009(HP)**

**NO DoE/CE/TEC/ Corrigendum/ Hamshu-I (SHP)/2017 685 FTO Dated:-22-11-17**

Copy for information and necessary action to the:

1. Addl. Chief Secretary (MPP & Power) to H.P. Govt., Shimla-171002(HP).
2. Addl. Chief Secretary (NES) to H.P. Govt., Shimla-171002(HP).
3. Secretary, Ministry of Non-Conventional Energy Sources (MNES), Block No.14,CGO Complex, Lodhi Road, New Delhi-110003.
4. Director, Environmental & Scientific Technologies, Narayan Villa, Near Wood Villa Palace, Shimla-171002(HP).
5. General Manager (C&D), HPPTCL, Himfed Bhawan, Panjari, Below MLA quarters, Shimla-171005 (HP) with reference to this office letter No.
6. Chief Engineer (System Planning), HPSEB Ltd, Dogra Lodge, Shimla-171004 (HP).
7. Chief Engineer(Commercial), HPSEB Ltd, Vidyut Bhawan, Shimla -171004(HP).
8. Chief Executive Officer, Himurja, 8A-SDA Complex, Kasumpti, Shimla-171009(HP).
- ✓ 9. M/S Hamshu Hydel Power, C/o Khayali Ram, Vill, Bulang, P.O. Fozal, Tehsil & District Kullu-175129 (HP)

  
**Chief Engineer, 24/11/17**  
**Directorate of Energy,**  
**New Shimla-171009(HP)**