


COMPLIANCE REPORT AGAINST OBSERVATION DATED. 05-09-2016
(FOREST PROPOSAL REF. NO: FP/AS/TRANS/19330/2016)

OBSERVATION	COMPLIANCE
1. FRA 2006 certificate is wanting	FRA compliance certificates obtained from the Deputy Commissioners of Kokrajhar and Chirang have been uploaded in the FORM-A (Part-1)
2. An undertaking certificate for the payment of additional NPV.	Copy of undertaking for payment of additional NPV is uploaded as additional information.
3. The total number of towers in each RF and their GPS coordinates.	Statement showing R.F/Forest Division wise breakup of total towers/height of towers/distance between adjacent towers/base area of towers/GPS coordinate in <i>degree-minute-second</i> format is uploaded as additional information in FORM-A (Part-1) as follows: • Haltugaon Forest Division:- ANNEXURE-VI • Chirang Forest Division :- ANNEXURE-VII • Kachugaon Forest Division: ANNEXURE-VIII
4. Height of each Towers	
5. Distance between the Towers	
6. Distance between the ground and the lower point of the conductor of the transmission line	The minimum distance (<i>i.e. ground clearance</i>) maintained between the ground and lowest point of the conductor of the Transmission Line is 8.84 meter . This is in accordance with IE rule, 1956 (as amended) Rule:77-9
7. Total base area of the towers	Statement showing RF/Forest Division wise breakup of total towers/height of towers/distance between adjacent towers/base area of towers/GPS coordinate in <i>degree-minute-second</i> format is uploaded as <u>ANNEXURE-VI</u> as additional information in FORM-A (Part-1)
8. All the GPS coordinates given in degree Decimal Unit may be converted to degree Minute Second Unit and uploaded as additional information	

For & On Behalf of POWERGRID


 बी. पॉल चौधुरी / B. Paul Choudhury
 उप महा प्रबन्धक / Dy General Manager
 पावरग्रिड, उ.पु.क्षेत्र / POWERGRID, NER
 उप केंद्र बongaigaon-साताकटी/Bongaigaon-Satakat S/S