

SNOWFOAM ENERGY PRIVATE LIMITED

House No.99, Ward No.8, Dhalpur, Kullu – 175101

Email: gangananna@gmail.com

Ph:01902 222120

Ref. no. SEPL/ DFO/ FCA/ 2021-22/ 15
Reminder Endst.No.Ft.48-4024/2019(FCA) Shimla, dt. 09-09-2021

The Divisional Forest Officer,
Kullu Forest Division,
Kullu, Dist. Kullu (H.P.).

Sub :- Diversion of 0.5705 ha. (instead 0.5948ha) of forest land in favour of Snowfoam Energy Pvt. Ltd. House No. 99, Ward No. 8, Dhalpur, Kullu for the construction of Hamsuh-1 SHEP 2.00 MW within the jurisdiction of Kullu Forest Division, distr. Kullu, H.P.

Sir,

With reference to the Government of India Ministry of Environment, Forest & Climate Change letter No 8B/H.P/01/52/2020/F.C./539 dated 03/07/2020 the point wise reply to the observations raised are as under :-

1. The Revised Techno Economic Clearance is under process for which we have deposited Rs. 20,000.00(Twenty thousands) on 30th July 2021 in favor of Superintending Engineer, Directorate of Energy, Shimla through a demand draft comprising no.118692, a copy of the same is attached with FCA file. As and when we receive the same will be submitted to your good office before final approval under FCA 1980. (Attached at Page No. 49-51)
2. Supplementary implementation Agreement is placed in each proposal folder at page no.52-55)
3. It is submitted that we have achieved the Power evacuation letter & Plan form HP Power Trans. Corp. Limited as per Letter No. HPPICL/TEC-Vol-IV/2021.7448-49 dated 25-08-2021. Page No. 56-57
4. As per your guideline for 33KV, the hon'ble High Court of H.P. passed orders in CWP No. 2313 of 2021 dt. 09-04-2021 to the Revenue deprt. to provide 600mm width for single circuit under ground Trans. line.
5. Plantation scheme of 1190 trees are placed at each proposal folder at page no. 37-48.
6. River Basin study of this river has already been received by the Nodal officer, Chief Conservator of Forest (FCA) from the Directorate of Energy, Shimla-9. Copy attached at page no. 58

Under instructions from the department of forest, we have reduced the diversion of forest land and the Forest area proposed for diversion is 0.5705 ha. (Instead of 0.5948 ha) As per the final proposal, the RoW for underground cable T/L of 1 mtr. Corridor is avoided. 600 mm width underground cable line for single circuit is proposed. As per the Forest conservation act 1980, the barest minimum land has to be diverted.

We are submitting six no. of sets of revised documents of Forest case.

You are therefore requested to kindly send the documents to the concerned Forest Authorities for diversion of Forest Land.

Thanking You Sir.

Kullu
06-10-2021

N. Prasad Rao
Director

*Received Copy
01/10/2021
01/10/2021*