

Attunli HEP (680 MW)

D. Reason for not providing such map

Various alternatives of the Project are studied before finalization as per some general criteria established by Central Electricity Authority (CEA), Govt. of India. Some of the criteria are: (a) Limits of Level provided by Govt. of Arunachal Pradesh during allotment of the project, (b) Installed Capacity of the Project as approved by CEA, (c) Type of the Project and other Technical parameters. The project scheme proposed in the Detailed Project Report has been arrived at after carrying out a detailed field and desk assessment of several alternative layouts, including the one proposed by NHPC in the Pre-Feasibility Report (PFR). Three different locations of the dam were studied before finalizing the proposed location based on a techno-economic evaluation. The powerhouse location was selected considering 1km free flowing river stretch upstream of the tip of reservoir of the downstream project as well as topographic and geological features. However, finalized Project Map (as also submitted to CEA) is enclosed with the diversion proposal of Attunli HEP (680 MW).