

गुगल एअर फोटो आधारित नक्शा
गुगल एअर फोटो आधारित नक्शा

HINDUSTAN PETROLEUM CORPORATION LTD.		R/O	
PROPOSED SITE & LAYOUT PLAN OF		VILLAGE = BHAKKALAN	
HODAL PATAUDI ROAD (MDR-132)		KHWAT/CHAKRA NO. = 240/270	
NEAR K.M. STONE-75(RHS)		MUTTL. NO. = 125, 149	
AT VILLAGE BHORAKALAN		KILA NO. = 3, 23	
TEHSIL FARUKH NAGAR, DISTT. GURGAON		NEAREST POLICE STATION = PATAUDI	
(HARYANA)		NEAREST RAILWAY STATION = GURGAON	
LIC. NO. = NEW PROPOSAL		TEHSIL = FARUKH NAGAR	
DISTT. = GURGAON		STATE = HARYANA	
APPD. BY		DATED: 15.02.2012	
Email: msp@hpcorpltd.com		PH. NO. 9992034101/1010375/30	
DRAWN BY: VASTUKRITI CONSULTANTS		C-5/114, 2nd FLOOR	
DELHI-110085		V.K.C. ASSOCIATES	

1. CERTIFIED THAT THERE IS NO OTHER STRUCTURE WILL BE ERRECTED NOR ANY OTHER SERVICE RENDERED EXCEPT THAT CONNECTED WITH THE PETROL PUMP WITHOUT THE PRIOR APPROVAL OF P.W.D.
2. CERTIFIED THAT THERE IS NO ROAD CROSSING WITH IN 100M BETWEEN THE TANGENT POINT OF THE CURVE OF SIDE ROAD AND THAT OF THE FUEL FILLING CUM SERVICE STATION.
3. CERTIFIED THAT THERE NO OBSTACLE FROM ROAD POINT OF VIEW FOR THE INSTALLATION OF THIS PUMP.
4. CERTIFIED THAT NO OTHER PETROL PUMP EXISTS WITHIN THE DISTANCE OF 300M ON EITHER SIDE OF THE PLOT.
5. CERTIFIED THAT THE BEING PORTION IS NOT INCLUDED IN THE AREA OF LAND TO BE LASED FROM P.W.D. FOR OPENING ROAD.
6. CERTIFIED THAT THE CONDITIONS LAD DOWN BY THE GOVT. OF INDIA AND HPC FROM TIME TO TIME WITH THE LOCATION OF ROAD SIDE FUEL FILLING STATIONS HAVE BEEN COMPLIED WITH ENTIRE CONSTRUCTION.
7. NO DRAIN/SEWER OR STRUCTURE WITHIN 1.5M FROM U/G TANKS.
8. SUCTION PIPE UNDER THE DRIVEWAY HOUSED IN PIPES SLEEVES.
9. ELECTRIC FITTINGS CONFORM TO ISS CODE NO 2148 FOR DISPENSING PUMP ONLY.
10. D/S BOARD 1.5M HIGH FROM FLOOR LEVEL AND WILL NOT BE KEPT UNDER LOCK AND KEY.
11. TANKS TO BE TANK LOCKED.
12. 40MM DIA. VENT PIPES 1.5M HIGH FROM G.L. AND 4M CLEAR AROUND THE OPEN END OF TANKS TO BE TANK LOCKED.
13. VENT PIPES COVERED WITH TWO LEAFS OF NON CORRODIBLE METAL WIRE GAUGE OF 11GHS PER CM.
14. NO HEDGES AND PLANTS MORE THAN 80CM HIGH SHOULD BE GROWN AROUND THE BUFFER.
15. THERE SHOULD BE SUFFICIENT STANDING SPACE IN SIDE THE STATION FOR VEHICLES TO WAIT FOR THEIR TURN.
16. IN AND OUT SIGNS ARE PUT UP TO GUIDE VEHICLES DURING THE DAY AND ARE PROPERLY LIT UP TO GUIDE THEM AT NIGHT.
17. NO SMOKING SIGN/PINE EXTINGUISHER AND FIRE BUCKETS PROVIDED AT SITE.
18. CERTIFIED THAT BUFFER SHOULD NOT HAVE ANY INSTALLATION, UNDER GROUND TANKS ETC.
19. CERTIFIED THAT THE KEROSENE STONE ALONG BURNER IS TO BE MADE BY COMP.
20. CERTIFIED THAT THERE WILLING BE ANY WORK/WORK FROM GROUND LINES AND POLES.
21. CERTIFIED THAT THE SURPLUS WATER WILL NOT BE DISPOSED OFF IN ROAD.
22. CERTIFIED THAT ALL CLAIMANCES/APPROVAL FROM MOPHE & OTHER RELEVANT GOVT. DEPTS. HAVE ALREADY BEEN OBTAINED.
23. CERTIFIED THAT THERE IS NO COURT CASE PENDING IN ANY COURT OF INDIA AGAINST THIS PREMISES.
24. CERTIFIED THAT THIS IS NOT A RESIDENT CASE.
25. 16/45ML STEEL TANK HAS BEEN FABRICATED AS PER DRG. APPROVED BY
- CODE NUMBER VIDE HIS LETTER NO. - P-6 (3) SO OF DATED 6.10.02.

AREA DETAIL
TOTAL PLOT AREA
169640 SQ.M.
TOTAL BUILDING AREA
4524 SQ.M.
TOTAL CANOPY AREA
26040 SQ.M.

NOTES & CERTIFICATES

