

Himachal Pradesh  
Irrigation and Public Health Department  
No. IPH-SNR-WS-WA-Miscellaneous -NOC /2013- 18531-35  
To

Dated:- 26/9/13

The General Manager  
TM &TP HEP's HPPCL at Sujanpur Tihra  
Distt. Hamirpur Pin-176110.

Subject: Request for insurance of NOC in respect of Thana Plaun HEP (Revised Capacity 191 MW) of HPPCL in river Beas Basin of HP.

Sir,

In pursuance to Principal Secretary (IPH) to the Govt. of HP Shimla letter No. IPH-B(F)5-4/2006 dated 29-8-2007, no objection certificate is hereby granted in favour of the General Manager TM &TP HEP's HPPCL at Sujanpur Tihra Distt. Hamirpur for the execution of above project subject to the following conditions:-

1. The firm shall enter into legal agreement with the department by signing an agreement with Executive Engineer, I&PH division, Mandi and Padhar.
2. All the conditions of the agreement so signed shall be strictly adhered to by the firm.
3. The department reserves the right to use water of Beas River for its existing as well as proposed schemes. The requirement of department shall have precedence over requirement of firm under all circumstances.
4. Permission to make alternative arrangements will be given subject to the condition that the arrangement will not affect adversely any existing or proposed water supply sources being used by the I&PH Department. It will be located at a sufficient distance from an existing ground water source and down-stream of any existing surface water source. It will also require approval of Gram Sabha of concerned Gram Panchayat before execution of the project.
5. The NOC and permission to make alternative arrangements shall be granted by IPH Executive Engineer concerned.
6. The firm shall ensure that the quantum of minimum flow of water to be released and maintained through out the year immediately downstream of the diversion site is a threshold value of not less than 15% of the minimum in flow observed in the lean season, to the main river water body whose water is being harnessed by the project. The firm shall also ensure adequate minimum environmental flow in the river below the diversion site to take care of aquatic life and ecology of the area.
7. An alternative arrangement will have to be made by project agency well in advance in case running water supply schemes/ irrigation is effected so that supply of water is not disrupted.
8. In case intake point of the existing scheme get disturbed an alternative arrangement should be made at the first instance before taking up of the work of project in hand.
9. The amounts intimated vide this office letter No. IPH-SNR-EA-Misc-NOC/2013-18022 dated 11.9.2013 to be paid to the IPH Department should be confirmed by project agency in writing before signing agreement.
10. As per direction of Addl. Chief Secretary IPH to the Govt. of HP efforts will have to be made by project agency for getting permission of FCA for relocation of structures of IPH Department.
11. In the event of violation of aforesaid terms and conditions of the NOC by the firm, the NOC shall be treated as cancelled with out any notice.



DGM/SR. MANAGER

MANAGER

DEPUTY MANAGER

P&A, F&A, R&A

with reference to their office letter No. IPH-B(F)5-4/2006 dated 29-8-2007 for favour of information please.

favour of information please.

of information please.

Copy forwarded to the Executive Engineer, I&PH Division, Mandi and Padhar with reference to their office letter No. 18031 dated 8.11.2012 & No. 9209 dated 31.5.2013 for information and necessary action.

Superintending Engineer,  
I&PH Circle Sunder Nagar.

Superintending Engineer  
I&PH Circle Sunder Nagar.