

TANGEDCO

From

To

Er. G. Sivasankaran, B.E.,
Assistant Engineer,
Operation and Maintenance,
TANGEDCO, RII/Sendurai,
Ariyalur.

The Principal Chief Conservator of Forests
(Head of Department),
Panagal Building,
Saidapet,
Chennai - 15.

Respected Sir,

Sub: Forests - Forest (Conservation) Act, 1980 - Trichy Circle/ Ariyalur Division - Proposal for diversion of 0.3996 ha. of forest land for erection of 11 KV feeder (HT) EB Posts from Ayyur to Vallam and Idayankuruchi villages across Ayyur RF and Kuvagam RF - Online proposal - Further details submission of - Reg.

Ref: (1) Online application No.FP/TN/Others/45417/2020 Dt.24.05.20 by Assistant Engineer, TANGEDCO, RII/Sendurai, Ariyalur.
(2) Principal Chief Conservator of Forests (Head of Forest Force), Chennai Ref.No. TS4/13227/2020 Dt.02.06.20.
(3) Principal Chief Conservator of Forests (Head of Forest Force), Chennai Ref.No. TS4/13227/2020 Dt.28.10.20.

Concerning the above subject, I submit the further details called for in the Principal Chief Conservator of Forests reference (3) cited are as follows:

- (1) The proposed 11 KV HT Line passes through along the roadside of District / Panchayat Roads parallel between Ayyur and Vallam villages across Ayyur and Kuvagam RFs.
- (2) Chapter 10 of Forest Conservation Act, 1980 enclosed with reference (3) cited reveals that the default right of way for 11 KV transmission line is 7 meter, however, the barest minimum width of the right of way of 0.3996 ha. is enough for the erection of 11 KV feeder (line) which passes along the roadside.
- (3) The minimum clearance between the conductor and the trees of the forest area is well maintained i.e 2.6 meter.
- (4) The alignment route does not have any deviation, since the line passes parallel with the roadside.

This is for the favour of kind information and early order.


12.11.2020
ASSISTANT ENGINEER,
O&M RURAL 2,
TANGEDCO,
SENDURAI 621 714