

TANGEDCO

From

To

Er. E. Sangeetha, B.E.,
Assistant Engineer,
Operation and Maintenance,
TANGEDCO, Andimadam/South,
Ariyalur.

The Principal Chief Conservator of Forests
(Head of Department),
Panagal Building,
Saidapet,
Chennai - 15.

Respected Sir,

Sub: Forests - Forest (Conservation) Act, 1980 - Trichy Circle/ Ariyalur Division - Proposal for diversion of 0.0768 ha. of forest land for erection of 11 KV feeder (HT) EB Posts from Ayyur to Pukkuzhi villages via Silambur across Kanguli and Thirukkonam RF- Online proposal - Further details submission of - Reg.

Ref: (1) Online application No.FP/TN/Others/45416/2020 Dt.24.05.20 by Assistant Engineer, TANGEDCO, South Andimadam, Ariyalur.
(2) Principal Chief Conservator of Forests (Head of Forest Force), Chennai Ref.No. TS4/13226/2020 Dt.02.06.20.
(3) Principal Chief Conservator of Forests (Head of Forest Force), Chennai Ref.No. TS4/13226/2020 Dt.28.10.20.

Concerning the above subject, I submit the further details called for in the Principal Chief Conservator of Forests reference (3) cited are as follows:

- (1) The proposed 11 KV HT Line passes through along the roadside of District / Panchayat Roads parallelly between Ayyur and Pukkuzhi villages via Silambur across Kanguli and Tirukkonam RFs.
- (2) Chapter 10 of Forest Conservation Act, 1980 enclosed with reference (3) cited reveals that the default right of way for 11 KV transmission line is 7 meter, however, the barest minimum width of the right of way of 1.0668 is enough for the erection of 11 KV feeder (line) which passes along the roadside.
- (3) The minimum clearance between the conductor and the trees of the forest area is well maintained i.e 2.6 meter.
- (4) The alignment route does not have any deviation, since the line passes parallel with the roadside.

This is for the favour of kind information and early order.


ASSISTANT ENGINEER
Operation & Maintenance,
TANGEDCO,
South/ANDIMADAM-621 801.