



H.P. POWER TRANSMISSION CORPORATION LIMITED

(A State Government Undertaking)

HIMPED Bhawan, Panjari, New ISBT Road

SHIMLA - 171005

CIN: U40101HP2008SGC030950

ANNEXURE-V

No. HPPTCL/Plg/TEC/Vol-IX/2021-7282-83 Dated: - 23/08/21

To

✓ **Chief Engineer (Energy),
Directorate of Energy, GoHP,
New Shimla, 171009.**



Sub: - Regarding Power Evacuation of (2 x 21 MW) Baggi HEP

Sir,

This is with reference to Transmission Part of DPR (Detailed Project Report) of Baggi HEP (2 X 21 MW) (Copy Enclosed) in receipt of HPPTCL for grant of TEC. BBMB vide their letter No.3995-97/CS/C-134/Vol-VI, dated-11.08.2021, (Copy Enclosed) have further clarified that the generation of the project is during lean period from 1st October to 20th April.

In this regard it is intimated that the Baggi HEP (2 x 41 MW) shall be evacuated by S/C LILO of Kangoo - Bajaura line subject to shifting of Malana-I HEP to 220/132 kV Charor Substation of HPPTCL.

It is further added that in case of any delay in shifting of Malana- I HEP to 220/132 kV Charor substation of HPPTCL, the power of the Baggi HEP shall be evacuated through the above arrangement with provision of SPS if required, as corridors for evacuation are expected to be relieved during the projected period of generation of Baggi HEP.

Yours faithfully,

**GM (C&D)
HPPTCL, Shimla-05**

Copy to-

1. Chief Engineer (System Planning) HPSEBL, Dogra Lodge, Shimla 171004.

**GM (C&D)
HPPTCL, Shimla-05**

Director (Energy)
C.E. (Energy) [Signature]
S.E. 1 (Dam, Env. LT Wb, SDA, Safety)
S.E. 2 (TEC)
S.E. 3 (Power Sale, SDA, Commercial Billing)
S.E. 4 (A&T, Policy, L&D, Legal, V.S., Monitoring)
Admin., Accounts & Finance

SE (TEC)

23/08/2021

Pl. file.

SE (TEC)

[Signature]

**Sr. Executive Engineer
Hydel Channel & Baggi Gate Divn.,
C.B.M.B. Sundernagar.**