



Haryana Public Works Department (Building & Roads)



From,

Sub Divisional Engineer,
Provincial Sub Division,
PWD B&R Br., Guhla.

To,

The Executive Engineer,
Provincial Division, No. II,
PWD B&R Br., Kaithal.

Memo No:- S/20

Dated:- 30.10.19

Subject:- Noc for putting up MS/HSD Retail outlet (Petrol Pump) at village Daba, Tehsil Guhla, District: Kaithal, State: Haryana, Khewat No. 117, Khatoni No. 158, Khasra No. 16/24/1, 17/2/2 Village: Daba District: Kaithal, State: Haryana.

Reference:- Division office Endst. No:- 12190 Dated:- 10/09/2019

In this connection, it is intimated that undersigned along with Sh. Balbir Singh J.E. visited the above said site. The site is situated at left hand side of Tatiana-Mehmoodpur road (sec. Sarola to Mehmoodpur road). As per plan received vide your letter under reference. This office has got no objection for installation of retail outlet on the subjected road subject to the following condition:-

1. The instruction for opening retail outlet as prescribed by IRC: 12/2009 will be strictly followed.
2. That no pucca constructed will be done within PWD land boundary.
3. That the natural profile of the road land width will not be disturbed on account of this proposed construction.
4. As per IRC 12/2009 POINT NO. 2 (Drainage) there shall be adequate drain system on the access to the fuel station and in said its area so as to ensure that surface water does not flow over the highway or any water logging takes place for this purpose, the fuel station & access area would be at least 300 mm below the level at the edge of the shoulder on the highway. The surface water from fuel station and access road would need to be collected in a suitable underground drainage system & led away to a natural course through culvert. Only slab culvert with iron grating of adequate strength shall be constructed in the approaches so that surface water is drained through the opening of in the grating. Construction of pipe culvert shall not be permission able for this purpose.