

Details of Transmission Towers Height Proposed in Forest Area

S. No.	Tower No.	Tower Type	Tower Height
1	27/0	DC	29.615
2	28/0	DB	29.465
3	28/1	DB	29.465
4	29/0	DC	29.615
5	30/0	DB	29.465
6	31/0	DB	29.465
7	32/0	DB	29.465
8	33/0	DB	29.465
9	34/0	DD	30.585
10	35/0	DC	29.615
11	36/0	DD	30.585

Minimum clearance between ground and lowest point of the conductor of transmission line shall be maintained more than **6.1 Mtrs.** at null point as per standard for 132 kV D/C Transmission Line.

