

S.NO.T-KSL-46/ 5531

Date-20/7/2020

The Executive Engineer
Kanwar Sen lift canal Div
IGNP, Loonkaransar

Sub:- Requesting for NOC. Construction of 765KV D/C(Hexa)Bikaner-Khetri Transmission Line

Ref:- Your Letter No.T-105/572 Dated 10.7.2020

With Reference to letter cited above vide which you have recommended the case to accord NOC for construction of 765KV DC(Hexa) Bikaner-Khetri Transmission Line crossing over the Kanwarsain lift canal near RD435(Near village Dandusar)

this contest the Permmision for overhead crossing of power line is here by conveyed with following conditions.

1. The flow of water in the Kanwar sain Lift Canal IGNP, Lunkaransar & both side, the inspection bank should not be obstructed, so as to inspection from both sides could be conducted.
2. The work will have to be got executed by the Bikaner-Khetri Transmission Ltd. Authority in running water and closure in Kanwar sain Lift Canal will not be provided in any conditions at any stage.
3. The restoration work of canal, if found and damage at the time to crossing of power line will have to got done then and there.
4. Tower for transmission line should be constructed 20' away from the canal banks.
5. The transmission line should be insulated over canal crossing reach.
6. The NOC for land required for any type of structure, be taken by the Bikaner-Khetri Transmission Ltd. from the respective competent authority.
7. The work will have to be got executed under the supervision of the Executive Engineer, kanwarsain Lift Canal IGNP, Lunkaransar.

The de-silting work of canal done by long Boom machines continuously (approx 60'long boom) therefore safe height of line cross over canal will be considered accordingly.


O / C Superintending Engineer
I.G.N.P., Sahwa Lift Circle,
Bikaner.

RITESH KUMAR VARMA


ASSOCIATE GENERAL MANAGER PROJECT
BIKANER KHETRI TRANSMISSION LTD.