

North Western Railway

DRM Office,  
Bikaner.  
Dt. 19.10.2020

No. 63-Elect/Xing/OH/2020 – 967

**Project Manager**  
**Bikaner Khetri Transmission Ltd.**  
**400KV RVPN GSS, Jaipur Road, Raisar, Bikaner - 334803**

**Sub:** 765 KV DC overhead power line track crossing at KM 293/1-2 between Jagdevwalla-Jagdevwala stations in LGH-SOG section.

**Ref:** Your office letter no. BKTL/Bikaner/B-K/31, dt. 28.01.2020.

-X-X-X-X-

In reference to above and instructions contained in Rly. Bd. letter no. 2010/Elect(G)/148/6 dt.30.01.17, following is to bring to your kind notice:

1. Subject to final verification of Railway boundary, permission is hereby accorded to execute the erection work of the above crossing without energization in the position and manner shown in Railway's approved drawing no. NW Rly. BKN Div. Sr.DEE/G-967/2020 submitted by you for approval and in accordance with the Agreement / Memo of terms incorporating the condition and specification therein and also the 'Regulation Governing' the placing of 'Electrical Transmission Line across the Railway Track' issued and as latest amended by Railway Board.
2. Under clause 3(II) of the Agreement / Memo of terms you are required to give a notice of sufficient days to the Senior Section Engineer (P Way), N.W. Rly at Lalgah and Asst. Engineer, N.W. Rly at Bikaner to enable them to take safety and precautionary measures where necessary before any work is actually commenced across or on the Railway Land and Track.
3. The SSE/S&T and Asst. Divisional Signal & Telecom Engineer concerned of the S&T Deptt. should also be addressed by you to enable them to check the safety arrangements for S&T line coming in this crossing area, to their satisfaction.
4. Permitted block time total 2 Hrs. Block will be provided in breaks as per the suitability of Railway.

It is requested to submit the joint inspection report to this office about the completion of construction work of the crossing. It may please be noted that electric crossing can be energized after prior approval of EIG from competent authority of SEBs/Owner of crossing and same is submitted with compliance certificate. The performa for joint inspection is attached herewith.

- DA:**
1. Copy of approved drawing mentioned above.
  2. Performa for joint inspection & compliance certificate

DIGITALLY SIGNED BY DRM/GWA  
SARVJIT KUMAR  
DRM (Electric)  
N.W. Railway, Bikaner

Copy forwarded for information and necessary action along with drawing to:

1. ADEN/Line/BKN
2. SSE(P Way)/LGH
3. SSE/Elect./LGH
4. SSE/Tele/LGH
5. SSE/Sig/LGH

Copy for kind information please:

1. Sr.DOM/BKN
2. DEN(S)/BKN
3. Sr. DSTE/BKN
4. Sr.DEE/TRD/BKN

**BITESH KUMAR VARMA**



ASSOCIATE GENERAL MANAGER PROJECT  
BIKANER KHETRI TRANSMISSION LTD.