



No. HSPCB/FR/2019/ 3058

Dated: 17/9/19

To

The Deputy Commissioner,
Faridabad.

Sub: Clarification regarding NOC for setting up Retail Outlet of Indian Oil Corporation Limited in the name of Sh. Parveen Fagna S/o Sh. Lajpat Rai, at location on "Faridabad City - 2, Faridabad district, Haryana. In "Kharsa No - 243/2/1, village Bhankri Faridabad, Haryana.

Ref: Your office memo No. 60/NOC/PP/4531-43/PLA dated 06.09.2019.

In this regard, it is submitted that as per Policy order dated 14-07-2016 of the Board, for Retail Outlet of MS/HSD Petrol Pump/Storage/LPG Cylinders/Station for dispensing of CNG/Storage of underground petroleum products is not covered under Consent Management of the Board but the unit is required to install pollution control measures and adhere to the prescribed standards.

Therefore as per site plan submitted by **Retail Outlet of Indian Oil Corporation Limited in the name of Sh. Parveen Fagna S/o Sh. Lajpat Rai, at location on "Faridabad City - 2, Faridabad district, Haryana. In "Kharsa No - 243/2/1, village Bhankri Faridabad, Haryana.** the Board has no objection for Retail Outlet of MS/HSD Petrol Pump subject to following conditions:-

1. The project proponent will obtain prior permission from Forest Department, Haryana before commencing of project.
2. The project proponent will obtain prior permission from Mining Department & Geology for excavation, if any during the installation of Plant & Machinery of the project.
3. The said Oil Company will set up the modern pollution Control checking equipment along with CCTV and video cameras etc. as per Head Office DO letter no. HSPCB / 2003 / 9883 dated 27/10/2003.
4. The said petrol pump / station will provide / install adequate safety measures regarding petroleum product which is hazardous in nature & fire extinguisher.
5. The unit will not alter the system and will not start any process i.e. service station without prior permission / NOC of Board.
6. The unit shall provide the acoustic chamber on D.G. Set and raise the height of D.G. Set exhaust pipe as per the norms of the Board.
7. The unit will provide green belt around the Petrol Pump.
8. At any stage, if storage site will be covered under consent / NOC management, then said unit will apply to the consent of the Board as per Law / Rule / Act / Direct of Government / Board.
9. The proponent shall obtain the Public Liability Insurance for the flammable gas storage under the provisions of the Manufacture, Storage and Import of Hazardous Chemicals Rules, 1989 read with PLI Act, 1991.


Regional Officer,
Faridabad Region