

(Please do not use fair paper unless required, it will preserve trees on earth)

Executive Engineer, Jagadhari Provincial Division, PWD (B&R), Br., Yamunanagar Email: :<u>pwd-eepd-yamunanagar@hry.nic.in</u> Web Page:@http://www.haryanapwdbandr.org

То

Sh. Lalit Kumar (Manager), POWER GRID, Corporation of India, 400/220 kv Sub Station, Rurkee-Dehradun Road, Puhana, Roorkee, Uttrakhand, Ph-9001890367 Email:-lalitsre@powergrid.in

Memo no. 1489 Dated: 11/05/2023

Subject: Regarding NOC for overhead crossing of PWD Roads by 132 KV D/C Jagadhari TSS (DFCCIL) – Tapri TSS (IR) Transmission line.

Ref.:

Your office letter No. NR1/ROORKEE/PWD/PL/ dated 21.04.2023.

In this connection, it is intimated that this office has no objection for over head crossing of PWD roads by 132 KV D/C Jagadhari TSS (DFCCIL) to Tapri TSS (Railway) T/L. under the location of pole structure and height of transmission line may be kept as per drawings. It must be ensure that the Horizontal and Vertical clearance of road shall also be as per IRC:32-1969 (copy enclose).

| Sr. No. | Name of road | Location No. | Spam (M) | Nearby Village | Clearance available vertical Mtrs. |
|---------|--------------------------|-----------------|----------|----------------|--|
| 1 | Mandebar to Harnaul | AP-6/0-AP7/0 | 320 | Mandebar | 11.14 |
| 2 | Yamunanagar to Radaur | AP-16/0-AP-17/0 | 320 | Damla | 13.90 |
| 3 | Yamunanagar to Karnal | AP-23/0-AP-24/0 | 320 | Kajuri | 11.192 |
| 4 | NH-344 to Khurdi | AP-21/0-AP-21/1 | 320 | Khurdi | 12.102 |

DA/Nil

Executive Engineer, Provl. Divn. PWD (B&R) Br. Yamuna Nagar