



Government of India
Ministry of Power
Central Electricity Authority
PSP&A-I Division

Sewa Bhawan, R. K. Puram, New Delhi-110066



[ISO: 9001:2008]

No. 1/3/2015/PSP&A-I/24-25

Dated: 6th January, 2016

To

Chairman and Managing Director,
Power Grid Corporation of India Limited,
Saudamini Plot No. 2, Sector-29
Gurgaon-122 001

Subject: Prior approval of Govt. of India under Section 68 of the Electricity Act, 2003 for "System Strengthening Scheme in Northern Region (NRSS-XXXVII)"

Reference: PGCIL's letter no. C/CP/NRSS-37 dated 26.11.2015

Sir,

Reference is invited to the above mentioned letter, seeking prior approval of Government of India under Section 68(1) of Electricity Act, 2003, hereinafter "the Act", for "**System Strengthening Scheme in Northern Region (NRSS-XXXVII)**", with following scope of works:

- (i) Establishment of 400/220kV, 7x105MVA GIS Substation in Jauljivi with following provisions:

400 kV side

- (a) 7x105MVA Single Phase ICTs along with ICT bays
- (b) 2 nos. of line bays
- (c) 2x63MVA switchable line reactors in Bareilly - Jauljivi 400kV D/C line at Jauljivi end
- (d) Space provision for 2 future bays

220 kV side

- (a) 2 nos. of ICT bays
 - (b) 8 nos. of line bays [Pithoragarh-2, Almora-2, Jauljivi-2 & Dhauliganga-2]
 - (c) One no. of 220kV sectionaliser
 - (d) Shifting of 25 MVA line reactor already available in 220kV Dhauliganga - Bareilly line at Dhauliganga end to 400/220kV Jauljivi substation as a bus reactor at 220kV
 - (e) Disconnection of 220kV LILO of Dhauliganga - Bareilly at Pithoragarh and connection of Pithoragarh line to Jauljivi 400/220kV Substation at 220kV
- (ii) LILO of both circuits of 400kV Dhauliganga - Bareilly (POWERGRID) line (presently charged at 220kV) at 400/220kV Jauljivi (POWERGRID) substation [Incoming line from Dhauliganga shall be charged at 220kV & outgoing to Bareilly shall be charged at 400kV]
- (iii) Diversion of Dhauliganga - Bareilly 400kV D/C line (operated at 220kV) at Bareilly end from Bareilly (UPPTCL) to Bareilly (POWERGRID) along with 2 nos. of 400kV bays at Bareilly.

The above scheme has been agreed in the 36th Standing Committee Meeting on Power System Planning of Northern Region held on July 13, 2015 at NRPC, New Delhi.


CEA conveys the prior approval of Government under Section 68(1) of Electricity Act, 2003 for – **"System Strengthening Scheme in Northern Region (NRSS-XXXVII)"** with the above mentioned scope of work to be implemented by POWERGRID. This approval is subject to compliance of:

- (a) The relevant provisions of the Act, as amended from time to time and the rules and regulations made there under, and
- (b) CEA (Measures relating to Safety and Electrical Supply) Regulations, 2010 and any subsequent amendments made thereto.

The approval is subject to the following conditions:

- (i) The implementing agency will commence construction of the project within three years of grant of approval, unless this term is extended by the Central Electricity Authority.
 - (ii) Central Electricity Authority may withdraw the approval before the expiry of the period of three years after giving a one month notice.
 - (iii) The implementing agencies shall abide by the provisions of Works of Licensee Rules, 2006 notified by the Govt. of India, Ministry of Power in the Gazette of India, extra-ordinary Part-II, Section 3(i) dated 18-04-2006 (vide GSR 217 (E) dated 18-04-2006).
- Provided that "nothing contained in this rule shall effect the powers conferred upon any licensee under section 164 of the Act"

Yours faithfully,

 61116

(P. D. Siwal)
Secretary

Copy for information to:
Joint Secretary (Trans),
Ministry of Power,
Shram Shakti Bhawan,
New Delhi- 11000