

# SHIV SHAKTI ENTERPRISES

REGN NO.997 FILE NO. 1831-DF

## Site Plan of Power Evacuation of Lower Bhagair S.H.E.P. 1 MW, V.P.O. Kunr, Teh. & District Chamba (H.P.)

The transmission line cum road has been proposed to connect our power house (P.H.) & switchyard with that of the Snow Dew S.H.E.P. 5 MW P.H. & Switchyard at Kareri V.P.O. Kunr Teh. & Distt. Chamba (H.P.)

The road cum transmission line is 887+12 meters long and 7 meters wide and this total area lying under Forest land (D.P.F.) has been diverted.

The transmission line shall be erected along the road as shown in the enclosed site plan.

We may inform that no green trees etc. are lying in the way of transmission line and the necessary tree enumeration certificate has already been issued by the authorities of Chamba Forest Division.

We have already submitted & uploaded this certificate with the main FCA case file.

The power generated from our P.H. shall be carried from Switchyard to the Switchyard of Snow Dew S.H.E.P. (5 MW) being the interconnection point through the above transmission line.

The total load shall be dispatched in a joint mode from the switchyard of Snow Dew S.H.E.P. through HT line (already commissioned) up to the 33 kv switchyard of HPSEBL sub station at Lahal Teh. Bharmour & Distt. Chamba, where the power shall be finally evacuated. This has the approval of D.O.E. of H.P. Govt. as per TEC.



A R SHARMA

Partner & Authorised Signatory

Shiv Shakti Enterprises  
Anurag Kutir, Lower Dohru, Ghuggar  
P.O. & Teh. Palampur (H.P.)-176061



D.F.O.

Chamba Forest Division  
Divisional Forest Officer  
Chamba Forest Division  
CHAMBA