



## SOUTH EAST U.P. POWER TRANSMISSION COMPANY LIMITED

409, Fourth Floor, Shalimar Titanium  
Vibhuti Khand, Gomati Nagar, Lucknow-226010, Uttar Pradesh  
CIN No.U40105UP2009PLC038216  
e-mail- info@seupptcl.com;

पत्रांक : SEUPPTCL / LKO/ 2023-34/ 601

दिनांक : 17.11.2023

सेवा में,  
प्रभागीय वनाधिकारी,  
फतेहपुर,  
उत्तर प्रदेश

विषय : प्रस्ताव संख्या FP/UP/TRANS/15538/2015 में लगायी गई आपत्तियों के निराकरण हेतु।

संदर्भ: नोडल अधिकारी के पत्रांक संख्या 60 /11-सी - FP/UP/TRANS/15538/2015, लखनऊ, दिनांक: 07 जुलाई

महोदय,

उपरोक्त संदर्भित पत्रांक के क्रम में आप को अवगत कराना है कि 765 के० वी० एकल परिपथ मैनपुरी - बारा पारेषण लाइन सर्किट-1 में आपत्तिओं के निराकरण हेतु फतेहपुर वन प्रभाग के अंतर्गत क्रम संख्या 3 में वर्णित आपत्ति के संबंध में दस्तावेज की मांग की गयी है।

इस संबंध में आप को अवगत कराना है कि विद्युत पारेषण लाइन के ओवरहेड क्रॉसिंग के लिए वन विभाग, राष्ट्रीय राजमार्ग एवं रेल लाइन से अनापत्ति प्रमाण पत्र लेने का प्रावधान है। राज्य मार्ग, नहर विभाग को केवल ओवरहेड लाइन क्रॉसिंग के लिए सूचित किए जाने की आवश्यकता होती है जिसकी सूचना संबंधित विभाग को दे दी गई है और सभी पावती प्रस्ताव में संलग्न है।

आपसे विनम्र अनुरोध है कि उपर्युक्त प्रस्ताव को अपने स्तर से निस्तारित करते हुए वन संरक्षक प्रयागराज को अग्रेषित करने कष्ट करें।

धन्यवाद

संजय कुमार सिंह  
महाप्रबंधक - पारेषण



62  
प्रभागीय निदेशक  
सांवांवन एवं वन्यजीव प्रभाग  
फतेहपुर (उ०प्र०) 212601  
05180-224493



## SOUTH EAST U.P. POWER TRANSMISSION COMPANY LIMITED

Ref.No:SEUPPTCL/River/Canal/2014-15/ 1271

Date: 22.01.2015

To,  
Executive Engineer,  
Irrigation Department,  
Fatehpur Division  
Fatehpur (UP)

Subject: Intimation for River / Canal Crossing by Overhead Power lines.

Dear Sir,

Uttar Pradesh Power Transmission Corporation Limited has initiated transmission Projects through its SPV "South East U.P. Power Transmission Company Limited" and South East U.P. Power Transmission Company Limited is constructing the Project on BOOT basis.

The detailed surveys of the transmission lines are complete & the proposed lines are crossing the River / Canal as of the following details.

Sl.No	Transmission Line	River / Canal	Between Towers	Near Village	District	Vertical Clearance
01.	765kV S/C Mainpuri – Bara Ckt-1	Lower Ganga Canal, Fatehpur Branch	AP33/3-AP33/4	Sunderpur	Fatehpur	23.0m
02.	765kV S/C Mainpuri – Bara Ckt-2	Lower Ganga Canal, Fatehpur Branch	AP38/1-AP38/2	Karchulipur	Fatehpur	21.0m
03.	765kV S/C Mainpuri – Bara Ckt-1	Lower Ganga Canal, Fatehpur Branch	AP52/6-AP53/0	Khurmabad	Fatehpur	20.7m
04.	765kV S/C Mainpuri – Bara Ckt-2	Lower Ganga Canal, Fatehpur Branch	AP41/0-AP41/1	Musafa	Fatehpur	22.1m
05.	765kV S/C Mainpuri – Bara Ckt-1	Lower Ganga Canal, Fatehpur Branch	AP53/2-AP54/0	Khurmabad	Fatehpur	20.0m
06.	765kV S/C Mainpuri – Bara Ckt-2	Lower Ganga Canal, Fatehpur Branch	AP67/1-AP67/2	Khurmabad	Fatehpur	21.7m
07.	765kV S/C Mainpuri – Bara Ckt-1	Lower Ganga Canal, Fatehpur Branch	AP54/2-AP54/3	Jonia	Fatehpur	22.2m
08.	765kV S/C Mainpuri – Bara Ckt-2	Lower Ganga Canal, Fatehpur Branch	AP84/2-AP84/3	Besadi	Fatehpur	18.6m
09.	765kV S/C Mainpuri – Bara Ckt-1	Lower Ganga Canal, Fatehpur Branch	AP72/0-AP72/1	Besadi	Fatehpur	20.8m

We are submitting the plan and elevation details of the crossing for your information please.

Thanking You,

Yours Faithfully

Encl :-

1. Key Plan
2. Crossing Plan & Elevation Drawing

(R.L. Singh)  
General Manager



प्रभागीय निदेशक  
सांवांवन एवं वन्यजीव प्रभाग  
फतेहपुर (उ०प्र०) 212601  
05180-224493

## SOUTH EAST U.P. POWER TRANSMISSION COMPANY LIMITED

409, Fourth Floor, Shalimar Titanium  
Vibhuti Khand, Gomati Nagar, Lucknow-226010, Uttar Pradesh  
CIN No. U40105UP2009PLC038216  
e-mail- info@seupptcl.com;

No. : SEUPPTCL / LKO / 23-24/ 547

Date : 11/10/23

To,  
Executive Engineer,  
Irrigation Department - PWD,  
Fatehpur,  
Uttar Pradesh

**Subject : Intimation of Dhala Adauli Canal Crossing by 765kV S/C Mainpuri - Bara ckt-1 Transmission Line.**

Sir,


This is to apprise you that SEUPPTCL is developing 765kV S/C Mainpuri - Bara ckt-1 transmission line under 765kV Mainpuri - Bara Line with 765/400 kV AIS at Manpuri and Associated Schemes/Works.

The said line is crossing over the subject cited canal near village - Sarauli as of the following details:-

Sl.No.	Transmission Line	River / Canal	Between towers	Proposed	Near Village	District	Vertical Clearance
1.	765Kv S/C Mainpuri - Bara ckt-1	Dhala Adauli Canal	AP72/0 - AP72/1		Besandi	Fatehpur	23.8m

We are submitting the plan and elevation details of the crossing for your information please.

Thanking You.

  
S.K. Singh  
General Manager - Transmission

Encl :

1. Checklist.
2. Tower Schedule
3. Tower Profile.



प्रभागीय निदेशक  
सांवांवन एवं वन्यजीव प्रभाग  
फतेहपुर (उ०प्र०) 212601  
05180-224493





# SOUTH EAST U.P. POWER TRANSMISSION COMPANY LIMITED

409, Fourth Floor, Shalimar Titanium  
Vibhuti Khand, Gomati Nagar, Lucknow-226010, Uttar Pradesh  
CIN No.U40105UP2009PLC038216  
e-mail- info@seupptcl.com;

No.: SEUPPTCL / LKO / 23-24/479

Date : 04.09.2023

To,  
Executive Engineer,  
Irrigation Department - PWD,  
Dhala Adauli Canal Division,  
Fatehpur,  
Uttar Pradesh

**Subject : Intimation of Dhala Adauli Canal Crossing by 765kV S/C Mainpuri - Bara ckt-1 Transmission Line.**

Sir,

This is to apprise you that SEUPPTCL is developing 765kV S/C Mainpuri - Bara ckt-1 transmission line under 765kV Manipuri - Bara Line with 765/400 kV AIS at Manpuri and Associated Schemes/Works.

The said line is crossing over the subject cited canal near village - Sarauli as of the following details :-

Sl.No.	Transmission Line	River / Canal	Between Proposed towers	Near Village	District	Vertical Clearance
1.	765Kv S/C Mainpuri - Bara ckt-1	Dhala Adauli Canal	AP81/1 - AP81/2	Kishanpur	Fatehpur	16.1m
2.			AP83/1 - AP83/2	Pahora		17.0m
3.			AP83/4 - AP84/0	Sarauli		21.3m
4.			AP86/0 - AP86/1	Banehaar		19.1m
5.			AP95/5 - AP96/0	Dhata		18.4m

We are submitting the plan and elevation details of the crossing for your information please.

Thanking You.

S. K. Singh  
General Manager - Transmission



Encl :

1. Checklist.
2. Tower Schedule
3. Tower Profile,

प्रभागीय निदेशक  
सांवांवन एवं वन्यजीव प्रभाग  
फतेहपुर (उ०प्र०) 212601  
05180-224493





# SOUTH EAST U.P. POWER TRANSMISSION COMPANY LIMITED

409, Fourth Floor, Shalimar Titanium  
Vibhuti Khand, Gomati Nagar, Lucknow-226010, Uttar Pradesh  
CIN No. U40105UP2009PLC038216  
e-mail- info@seupptcl.com;

No.: SEUPPTCL / LKO / 23-24/ 556

Date: 11/10/23

To,  
Executive Engineer, - CD-2  
Public Works Department,  
Fatehpur (UP)

Subject: Intimation for SH / MDR Crossing by Overhead Power lines.

Dear Sir,


Uttar Pradesh Power Transmission Corporation Limited has initiated transmission Projects through its SPV "South East U.P. Power Transmission Company Limited" and South East U.P. Power Transmission Company Limited is constructing the Project on BOOT basis.


The detailed surveys of the transmission lines are complete & the proposed line is crossing the State Highways / MDRs as of the following details.

Sl.No	Transmission Line	SH Crossing	Between KMs	Between Angle Points	Near Village	District	Vertical Clearance
01.	765KV S/C Mainpur - Bara ckt-1	SH-71 (Fatehpur - Ghazipur)	Near Village Natrauli	AP67/5-AP68/0	Natrauli	Fatehpur	20.80m

We are submitting the plan and elevation details of the crossing for your information please.

Thanking You,

  
S. K. Singh  
GM - Transmission

  
13/10/23

Encl:

1. Tower Schedule.
2. Dwg / Profile of Crossing details.



प्रभागीय निदेशक  
सांवांवन एवं जन्यजीव प्रभाग  
फतेहपुर (उप्र) 212601  
05130-224493



SOUTH EAST U.P. POWER  
TRANSMISSION CO. LTD.

# SOUTH EAST U.P. POWER TRANSMISSION COMPANY LIMITED

409, Fourth Floor, Shalimar Titanium  
Vibhuti Khand, Gomati Nagar, Lucknow-226010, Uttar Pradesh  
CIN No.U40105UP2009PLC038216  
e-mail- info@seuptcl.com;

No. : SEUPTCL / LKO / 23-24/ 559

Date : 11/10/23

To,  
Executive Engineer, - CD-2  
Public Works Department,  
Fatehpur (UP)

**Subject: Intimation for SH / MDR Crossing by Overhead Power lines.**

Dear Sir,

Uttar Pradesh Power Transmission Corporation Limited has initiated transmission Projects through its SPV "South East U.P. Power Transmission Company Limited" and South East U.P. Power Transmission Company Limited is constructing the Project on BOOT basis.

The detailed surveys of the transmission lines are complete & the proposed line is crossing the State Highways / MDRs as of the following details.

Sl.No	Transmission Line	SH Crossing	Between KMs	Between Angle Points	Near Village	District	Vertical Clearance
01.	765KV S/C Mainpuri - Bara ckt-1	SH-32 (Choudhagra - Jahanabad)	Near Bakewar	AP38/0- AP39/0	Bakewar	Fatehpur	21.70m

We are submitting the plan and elevation details of the crossing for your information please.

Thanking You,

S. K. Singh

GM - Transmission

13/10/23

Encl :

1. Tower Schedule.
2. Dwg / Profile of Crossing details.



भ्रभागीव निदेशक  
सांवावन एवं वायुमय प्रभाग  
फतेहपुर (उप्र) 212601  
05180-224493