

- 251 -

Office of the Superintending Engineer,
Irrigation Circle, Khammam.

Memo.No.SE/IC/KMM/DB/DEE1/TO/1982-83/m Dt: 28.11.2019.

Sub:- TS-I Pass (Act-3 of 2014) - Allocation of Industrial water supply to ITC Ltd., PSPD Iravendi (V), Burgampahad (M), Bhadradri Kothagudem District - Replacement of Raw water line for the factory - Communications of observations of calculations - Permission to lay 1400 dia pipe with stipulations - Reg.

Ref:- ENC Memo. No. ENC(I)/DCE1/OT1/AEE5/M/s ITC Ltd.,/2018,
Dt: 07.11.2019.

As per the instructions contained in the reference cited above, permission is here by accorded for laying of 1400 mm dia Pipe line in place of the existing pipeline of 900mm dia to ITC Ltd., PSPD Iravendi (V), Burgampahad (M), Bhadradri Kothagudem District with a stipulation that the total quantity of water drawn shall be assessed from the two flow meters installed at pump house and intake well and ensure to limit the drawl within the allocated discharge of 17.60 MGPD per annum strictly.

The Executive Engineer, IB Division, Kothagudem is instructed to ensure to limit the drawl of water allocated to the factory and maintain the record of monthly drawl and monthly reports shall be submitted along with royalty paid in time.

Any deviations in drawl of water exceeding the allocated limits will be viewed serious and the Executive Engineer, IB Division, Kothagudem H.q@ Paloncha is directed to monitor the discharges regularly without fail.

Sd/-

Superintending Engineer, I&CADD.,
Irrigation Circle, Khammam.

To
The Executive Engineer,
IB Division, Kothagudem
H.q@ Paloncha.

✓ Copy communicated to ITC Ltd., PSPD, Factory at Sarapaka - 507128, Bhadradri Kothagudem District.



P. K. G. J.
Superintending Engineer, I&CADD.,
Irrigation Circle, Khammam.

28/11