



LOCATION DETAILS :	
KHASRA No. :	MURBBA NO. 11, KILA NO. 6 & 7
VILLAGE :	1G CHOTTI
PIN CODE :	335001
TEHSIL :	SRI GANGANAGAR
DISTRICT :	SRI GANGANAGAR
POLICE STATION :	SRI GANGANAGAR
RAILWAY STATION :	SRI GANGANAGAR
TOTAL AREA :	929.03 SQ. MTR.
STATE :	RAJASTHAN
CONTACT No. :	9414482834, 9799110089

- NOTES :-
- CERTIFIED THAT NO OTHER STRUCTURE WILL BE ERRECTED NOR ANY OTHER SERVICE RENDERED EXCEPT THAT CONNECTED WITH RETAIL OUTLET WITHOUT THE APPROVAL OF P.W.D. / LOCAL AUTHORITY.
 - CERTIFIED THAT BERM POSITION IS NOT INCLUDED IN THE AREA TO BE LEASED FROM P.W.D. FOR APPROACH ROAD, BUT TO BE METALLED BY THE COMPANY.
 - CERTIFIED THAT THERE IS NO ROAD CROSSING WITHIN 100.00M. BOTH SIDE FROM UNDER TANK.
 - TANK FED BY TANK LORRY.
 - PROPOSED WORK SHOWN IN RED.
 - CERTIFIED THAT ONE TANK WILL BE REPLISHED AT A TIME.
 - VENT PIPE 4.0M. ABOVE G.L. OR 1.5M. ABOVE CANOPY ROOF LEVEL COVERED WITH TWO LAYERS OF WIRE GAUGE NON CORROSIVE METAL NOT LESS THAN 11 MESH PER LINER CM.
 - CERTIFIED THAT NO OTHER RETAIL OUTLET EXIST WITHIN 300.00M. IN SAME SIDE AND 150.00M. CONSTRUCTION WILL BE ON OUR LAND.
 - CERTIFIED THAT THIS IS NOT A RESITEMENT CASE.
 - CERTIFIED THAT ALL THE CONDITIONS LAID DOWN BY GOVT. OF INDIA AND IRC FROM TIME TO TIME WILL REGARD TO LOCATION OF ROAD SIDE FUEL FILLING STATION HAVE COMPLIED WITH.
 - ALL ELECTRIC FITTING CONFORM TO IS:2148.
 - CERTIFIED THAT SHIFTING OF RETAIL OUTLET SHALL BE DONE AT OUR OWN CAST AS AND WHEN DEMAND BY THE GOVT. OF INDIA.
 - CERTIFIED THAT IRC RULES ARE FULFILLED.
 - CERTIFIED THAT NO COURT CASE IS PENDING AGAINST THAT PUMP OUTLET IN ANY COURT OF INDIA.
 - CERTIFIED THAT ALL THE CLEARANCES / APPROVALS FROM MOP, IRC AND RELEVANT DEPTT. HAVE ALREADY BEEN OBTAINED.
 - THERE IS NO ELECTRIC LINE CROSSING THROUGH OUT THE LINCENCE PREMISES.
 - 15KL/20KL/30KL/40KL TANK INSTALLATION AS PER APPROVAL OF C.C.E., CONFIRM TO IS-10987, EOL-MSTD/MCCOE/002 & EOL-MSTD/MCCOE/003 & EOL-MSTD/MCCOE/004 & EOL-MSTD/MCCOE/005.
 - 15KL/20KL/30KL/40KL TANK INSTALLATIONS AS PER APPROVAL OF C.C.E. NAGPUR VIDE HIS LETTER NUMBER P-6 (3) 71 DATED - 06.06.2006.
 - DPSB SHOULD BE KEPT 1.5M. HIGH FROM GROUND LEVEL.
 - CERTIFIED THAT CANOPY MEASURING 10M X 16M X 5.0M HIGH IS CONFIRMS TO SOUND ENGG. SPECIFICATIONS & THERE IS NO CHANCE OF ITS OVER CAVING IN UNDER NORMAL CIRCUMSTANCES.

04.08.2021	Facilities Shown As Per Requirements.		
DATE	REV.NO.	BRIEF RECORD	INITIAL

REVISION

NAYARA ENERGY LIMITED
FORMERLY ESSAR OIL LIMITED

SUBJECT:-
PROP. SITE & LAY OUT PLAN OF NAYARA ENERGY RETAIL - OUTLET ON SURATGARH - GANGANAGAR ROAD (CITY ROAD) IN THE PART OF MURBBA NO. 11, KILA NO. 6 & 7, AT VILL.

1G CHOTTI
TEHSIL:- SRI GANGANAGAR, DISTT:- SRI GANGANAGAR (RAJ.)

SCALE	ASHISH	REV
AS SHOWN	DRAWN BY Manager (RS)	2
DRAWING NO. - NAYARA - RJ - 300419383322 - 3396		

AGENCY:
UNIQUE DESIGN SOLUTIONS
51, Patel Nagar, Kalwar Road,
Jhotwara, Jaipur-12 (Rajasthan)
Mobile : 7073318481
Email:- unqueds2015@gmail.com

For Naya Energy Limited
[Signature]

NOTE FOR GENERAL SITING:-

- ACCESS ROAD SHOULD HAVE MIN. PAVEMENT OF 150 MM GSB, WBM GR. I, II, III OF 75MM EACH, 50 MM BM AND 30MM BC.
- ALL PAVEMENT MARKINGS SHOULD BE AS PER IRC: 35 - 1997.
- ALL TRAFFIC SIGNS SHOULD BE AS PER IRC: 67-2001 AND IRC: SP - 65 - 2001 IN CASE OF A FUEL STATION LOCATED ON THE OTHER SIDE OF TRAVEL DIRECTION THE USER SHOULD BE INFORMED OF THE LOCATION OF THE FUEL STATION IN HISHER DIRECTION OF TRAVEL THROUGH INFORMATION SIGNS AS AT C.O.F. THE TABLE OF THIS DRAWING.
- THE LENGTH OF SEPARATOR ISLAND SHOULD BE DETERMINED AS PER SITE CONDITIONS ITS MINIMUM WIDTH SHOULD NOT BE LESS THEN 3.00M.
- THE SEPARATOR ISLAND & BUFFER STRIP SHALL BE TURFED WITH PROVISION OF MIN. 275MM HIGH KERBS.
- CULVERTS TO BE PROVIDED IN THE LINE OF STORM WATER DRAIN ON ENTRY AND EXIT APPROACHES, TO CATER TO THE EXPECTED DISCHARGE.
- ALL THE DIMENSIONS ARE IN METRE UNLESS OTHERWISE SPECIFIED.

DETAIL OF FACILITIES								
TANK NO.	CAPACITY	PRODUCT	SIZE		STEEL PLATES		CONNECTIONS OF PUMPS	
			DIA.	LENGTH	SHELL	END	PROPOSED	COMMISSION
T-1	25000 LT.	MS (CL 'A')	2233 MM	7000 MM	6.00MM	8.00MM	2	
T-2	30000 LT.	HSD (CL 'B')	2450 MM	7000 MM	6.00MM	8.00MM	2	