





TYPICAL	
---------	--


1. The electric charging point shall be installed outside the extent of hazardous areas at the subject vessel as defined in Fourth Schedule, Article C of the Petroleum Rules 2002, and as marked in the drawing.
2. Sufficient space shall be provided for easy movement of vehicles in case of emergency and the vehicles shall always be parked in drive off position as all the
3. Adequate fire fighting facilities shall be provided at the electric Charging Points.
4. The Charging operation shall be carried out under strict supervision of skilled and trained personnel.
5. The Services station staff shall also be given safety training regarding the electrical vehicle charging operation.
6. The electrical cables/ Lines to be provided relating to installation of charging point are to be laid over underground.
7. The Vehicle battery charging area shall be clearly demarcated and appropriate display board shall be provided.
8. Charging points shall be used only for Charging of Electric Vehicles.



TYPICAL X-SECTION OF OFFICECANOPY
SIZE 12.0Mx14.20Mx6M HIGH



TANK DATA SHEET									
TANK	SIZE OF TANK	MS PLATES	NO OF SHEET	VINT PIPE	SLAB TH	TANK & P.W.			
20 ML	2.1M X 2.5M LONG	END	H.D.E	DIA	N.M.M	MS	IN	IN	IN
		6mm	8	40	—	1 + 1	1		

[illegible]