

Component wise breakup				
S.no	Component	length	breadth	Forest Land(ha.)
1	Inlet Chamber	3.5	2	0.0007
2	Bar Screen Chamber Manual	4	1	0.0004
3	Bar Screen Chamber Manual (Mech.)	4	1	0.0004
4	Bar Screen Chamber Manual (Mech.) Standby	4	1	0.0004
5	Grit Chamber Mech	7.6	5	0.038
6	SBR I-II Tank	41	24	0.0984
7	Chlorine Contact Tank	16	10	0.016
8	Sludge Sump	12	10	0.012
9	Chlorine Building	16	10	0.016
10	Process Air Blower Building	6	10	0.006
11	Indoor HT Substation	15	10	0.015
12	DIESEL GENERATOR ROOM	20	15	0.03
13	METER ROOM	5	2	0.001
14	GUARD ROOM	5	2	0.001
15	MCC ROOM	20	15	0.03
16	ADMIN BUILDING	6	10	0.006
17	MAINTENANCE WORKSHOP	20	10	0.02
18	SLUDGE DEWATERING BUILDING	10	10	0.01
19	APPROACH ROAD	45.6	5	0.0228
20	PATH	156	1	0.0156
21	OPEN AREA			0.0725
	Total			0.4122

Layout Plan Showing Construction of Sewerage Treatment Plant 3.10 MLD at Ashwani Khad.



Legend

- Proposed Site
- Approach Road
- Path

Assistant Engineer
Sewerage South Zone
SJPNL US Club
Shimla - 171001

Additional General Manager,
Sewerage Division SJPNL
US Club Shimla - 171001

Divisional Forest Officer
Shimla Division
SHIMLA

30

60 Meters