

To

SDO Construction,
HVPNL, Narnaul.

Memo No. **2995**

Dated: **9-5-22**


Subject: Submission of PWD NOC Proposal for Creation of LILO of 132 kV on D/C Tower from 400 kV S/Stn Dhanonda to 12 kV S/Stn Kanina.

Ref.: Your office letter No. 276 dated 11.04.2022.

In this connection, it is intimated that this office has no objection id HVPNL creates LILO of 132 kV on D/C Tower from 400 kV S/Stn Dhanonda to 132 kV S/Stn Kanina subject to condition that :-

1. Height of electric line passing over PWD road should not be less than 5.50mtr. from top of road surface.
 2. No poles should be installed/fixed on PWD land/ RoW.
 3. Any type of damaged to PWD road must be avoided. If the road is proposed to be raised/widened in future, the poles/line will be sifted by HVPNL at its own cost.
 4. Safety measures would be ensured by the HVPNL during the whole process.
- This is for your kind information and necessary action.

DA/Nil



Executive Engineer,
Provl. Divn. PWD B&R Br.,
Narnaul.

Endst No.

Dated

Copy forwarded to the Sub Divisional Engineer, Provl. Sub Divn., PWD B&R Br., Mohindergarh for information w.r.t his letter No. 659 dated 28.04.2022.

DA/Nil


Executive Engineer,
Provl. Divn. PWD B&R Br.,
Narnaul.