



SITE PLAN
SCALE : N.T.S

LAYOUT PLAN
SCALE:-1:250

AREA CALCULATION
PROTECTED FOREST FOR APPROACH ROAD
A+A' = 253.06+456.44 = 709.50 SQM.
TOTAL = 709.50 SQM. OR 0.07095 HAC.

TOTAL PLOT AREA - 1346.89 SQ. M. (0.134689 HAC.)

SPECIFICATION NOTES:-I

- CERTIFIED THAT NO OTHER STRUCTURE WILL BE ERRECTED NOR ANY OTHER SERVICE RENDERED EXCEPT THAT CONNECTED WITH PETROL PUMP WITHOUT THE PRIOR APPROVAL OF P.W.D.
- CERTIFIED THAT THERE IS NO CROSSING WITHIN 300M BETWEEN THE TANGENT POINTS OF THE CURVES OF SIDE ROAD AND THAT OF THE FUEL-FILLING CUM SERVICE STATION.
- CERTIFIED THAT THERE IS NO OBJECTION FROM ROAD POINT OF VIEW FOR THE INSTALLATION OF THIS PUMP. THE PROPOSAL WILL NOT AFFECT THE FUTURE IMPROVEMENT OF THE ROAD.
- CERTIFIED THAT NO OTHER PETROL PUMP EXISTS WITHIN THE DISTANCE OF 300M ON EITHER SIDE OF THE PLOT.
- CERTIFIED THAT ALL CONDITIONS LAID DOWN BY THE GOVT. OF INDIA AND IRC FROM TIME TO TIME WITH REGARD TO THE LOCATION OF ROAD SIDE FUEL-FILLING CUM SERVICE STATIONS SHALL BE COMPLIED WITH & ENTIRE CONSTRUCTION WILL BE ON CORPORATION LAND.
- NO DRAIN, SEWER OR STRUCTURE WITHIN 1.5M FROM UNDER GROUND TANKS.
- SUCTION PIPES, UNDER DRIVEWAY HOUSED IN PIPE SLEEVES.
- ELECTRIC FITTINGS CONFORM TO IS CODE NO-2148 FOR DISPENSING PUMP ONLY.
- DPS BOARD IS FIXED 1.5M HIGH FROM FLOOR LEVEL AND WILL NOT BE KEPT UNDER LOCK AND KEY.
- 40MM VENT PIPES, 4M HIGH FROM GROUND LEVEL AND 4M CLEAR AROUND. THE OPEN END OF VENT PIPE COVERED WITH TWO LAYERS OF NONE CORRODIBLE METAL WIRE GAUGE OF 11MESH PER LINER CM.
- 80MM FILL PIPES, TO BE PROVIDED 3.65M CLEAR ALL ROUND.
- FIRE FIGHTING EQUIPMENT:-
 - 6 NOS. FOAM TYPE OF FIRE EXTINGUISHERS OF CAPACITY 9KG EACH FOR PETROLEUM FIRE, 2NOS CO2 TYPE FIRE EXTINGUISHERS OF CAPACITY OF 3KG EACH FOR FIGHTING ELECTRICAL FIRE AND 6NOS. OF FIRE BUCKETS FILLED WITH DRY SAND SHALL BE PROVIDED AT THE PETROL PUMP.
 - CERTIFIED THAT THERE WILL NOT BE ANY HINDRANCES FROM OVER HEAD HT LINES.
 - CERTIFIED THAT THE SURPLUS WATER WILL NOT BE DISPOSED OFF ON P.W.D LAND.
 - CERTIFIED THAT ALL THE CONDITIONS OF IRC-1983/2003 SHALL BE COMPLIED WITH.
 - CERTIFIED THAT NO COURT CASE IS PENDING IN ANY COURT OF INDIA AGAINST THIS SITE/DEALERSHIP.
 - CERTIFIED THAT ALL THE CLEARANCES/APPROVALS FROM MCP/IRC AND OTHER RELEVANT GOVT. DEPTT. SHALL BE OBTAINED.
 - STEEL CANOPY CCE APPROVAL NO. - G-40 (NC) P-CANOPY dt. 26.07.89.
- MS TANK OF 20KL CAPACITY FABRICATED AS PER DRG. APPROVED BY CCE VIDE LETTER NO. P-3(9) 242/II DATED 05.12.1989.

AREA CALCULATION

PROTECTED FOREST FOR APPROACH ROAD
A+A' = 253.06+456.44 = 709.50 SQM.
TOTAL = 709.50 SQM. OR 0.07095 HAC.

IndianOil

INDIAN OIL CORPORATION LIMITED
(MARKETING DIVISION)
GURGAON DIVISIONAL OFFICE

PROJECT:- FUEL DESTINATION
ON REWARI-SOHNA-PALWAL ROAD, N.H.-71B,
(NEW N.H.-919) AT RD-28.240 (LHS), AT VILL.- KHORI KALAN,
TEH.-TAURU, DISTT.-MEWAT (HARYANA)

TITLE:- SITE & LAYOUT PLAN

DRAWN:- P.K. DRG. NO:- SAY/DO/FUEL DESTINATION FOREST

CHKD:- DATE:- 23.06.2013

APPRD:- SCALE:- 1:250

SALES OFFICER BY. MANAGER/SR. MANAGER-S&M

MANAGER- RETAIL SALES CDRSM

PREPARED BY:-
SHUBHAM ASSOCIATES
PLOT NO. 1346.89 SQ. M.
DATE 2013/06/20