



PLA
~~hit~~ June
CTM
23/6/14
②

To

The Deputy Commissioner,
Rewari.

Memo No. 8560

Dated

19-6-14

Subject : Grant of NOC for setting up New Kishan Seva Kendra retail outlet at village Niganiawas in Rewari Distt. (Haryana).

Reference: Your office memo. No. 9785-93/PLA dated 13.09.2013.

In this connection it is submitted that No Objection Certificate to IOC Ltd. is hereby issued by this office as decision taken in the meeting dated 30.05.2014 by the committee on the left hand side of Delhi -Jaipur NH-8, 1.00km away from Khijuri Chowk at village Niganiawas in Rewari Distt. on the following terms and conditions:

The company will provide a one meter width Box culvert at both the approaches.

1. The company will not construct Katcha or pucca structure on the PWD Land.
2. Level of approaches should be kept below the shoulder of the PWD road level.
3. The company will regulate the storm water drainage to avoid damage to the road.
4. The company will arrange the drainage of the area of retail outlet in such a manner so that its storm water does not flow on the PWD Land in any case.
5. The Longitudinal drainage of the road should not be affected in any manner.
6. The company will not provide any sign Board or hoarding which violates the instructions of Hon'ble High Court & Hon'ble Supreme court.
7. No Action of the company will be allowed which will affect smooth running of vehicles on the road.
8. Annual rent for lease charges of land will be paid by the company regularly as amended from time to time.
9. The proposed retail outlet fall on through road and it has been decided that drawing of proposed retail outlet should be got corrected and amended from the applicant in respect of plinth level building/shoulder of the road level which should be at least 300 mm below the road level.
10. Regarding construction of drainage system it has been decided that only slab type culvert with iron grating of adequate strength shall be constructed in the access, so that surface water drained through the opening of the grating

DA/Nil

Executive Engineer,
Provl. Division, PWD B&R Br.,
Rewari.

Endst. No.

Dated

Copy forwarded to the Superintending Engineer, Rewari Circle PWD B&R Br. Rewari for information and necessary action. w.r.t memo. No. 2887 dated 04.06.2014

DA/Nil

1
Executive Engineer,
Provl. Division, PWD B&R Br.,
Rewari.