

Government of Rajasthan  
Office of the Additional Chief Engineer, Vigilance, Quality Control &  
Regulation, Indira Gandhi Nahar Project, Bikaner.  
Teltax- 01512226408 e-mail acevrbikaner@gmail.com, aceregulation.wr@rajasthan.gov.in

No.T-26/R/ACE/VR/ 1546  
The Executive Engineer  
R.R.V.P.N.Ltd, Bikaner.

Dated. 8<sup>th</sup> November, 2018  
14

Sub- To provide NOC for the major branch (The area Main Canal RD593-  
RD 594, of IGNP Canal crossing for 220 KV D/C Gajner-Chattargarh  
Tr. Line.

Ref:- Your office letter No.  
RRVPNL/EE(T&C)/Bikaner/Tech./Estt./D.1013  
dated 30.10.2018


Sir,

With reference to letter cited above vide which you have submitted the case to accord NOC for the major branch (The area Main Canal RD593-RD 594, of IGNP Canal crossing for 220 KV D/C Gajner-Chattargarh Tr. Line.

In this contest, the permission for overhead crossing of power line to R.R.V.P.N.Ltd., Bikaner is here by conveyed with the following conditions:-

1. The flow of water in the Main Canal & both's side, the inspection bank should not be obstructed, so as to inspection from both's side could be conducted.
2. The work will have to be got executed by the R.R.V.P.N.Ltd., Bikaner Authority in running water and closure in IGMN will not be provided in any conditions at any stage.
3. The NOC for land required for any type of structure, be taken by the R.R.V.P.N.Ltd., Bikaner from the respective competent authority.
4. The restoration work of Canal, if found any damage at the time to crossing of power line will have to be got done then and there.
5. The work will have to be got executed under the supervision of the Executive Engineer, Regulation Division II Chattargarh.
6. The de-silting work of Main Canal done by Long Boom Machines continuously (approx 60' long boom) therefore safe height of line cross over canal will be considered accordingly.

Yours faithfully

  
(Vinod Mittal)  
Additional Chief Engineer  
Vigilance Q.C. & Regulation  
IGNP Bikaner  
Dated:

No.T-26/R/ACE/VR/

Copy forwarded to the following for information and needful action :

1. The Superintending Engineer, Regulation, Bikaner.
2. The Executive Engineer, Regulation Division II, Chattargarh.

**Additional Chief Engineer**

राजस्थान सरकार  
कार्यालय अधीक्षण अभियन्ता, द्वितीय चरण वृत्त प्रथम, इंगानप, बीकानेर।

क्रमांक :- टी-102/3524

दिनांक :- 1-11-18

प्रेषित :


✓ अधिशाषी अभियन्ता (टी एण्ड सी)  
राजस्थान राज्य विद्युत प्रसारण निगम लिमिटेड  
बीकानेर।

विषय :- To Provide NOC for the minor canal and distributory (The area Kanasar Distributory 6.620 KM's , Jageri Minor 7.550 KM's and Jaimalwala Minor 8.190 KM's) of IGNP canal crossing for 220 KV D/C Gajner-Chhattargarh Tr. Line.

प्रसंग :- आपका पत्रांक RRVPNL/Executive Engineer (T&C)/Bikaner/Tech.  
/Estt/D. 1015 दिनांक 30.10.2018

महोदय,

उपरोक्त विषयान्तर्गत आपके पत्र द्वारा वांछित 220 KV D/C Gajner-Chhattargarh Tr. Line. के लिए कानासर वितरिका के किमी 6.620, जगेरीवाला वितरिका के किमी 7.550 व जयमलसर वितरिका के किमी 8.190 पर उपरोक्त विद्युत लाईन को क्रॉस करने के लिए अनापत्ति प्रमाण-पत्र नहर की सुरक्षा को सुनिश्चित करते हुए जारी की जाती है।

  
अधीक्षण अभियन्ता  
द्वितीय चरण वृत्त प्रथम  
इंगानप, बीकानेर।

क्रमांक :- टी-102/

दिनांक :-

प्रतिलिपी अधिशाषी अभियन्ता, 20 वां खण्ड, इंगानप, बीकानेर को सूचनार्थ एवं आवश्यक कार्यवाही हेतु प्रस्तुत है।

अधीक्षण अभियन्ता  
द्वितीय चरण वृत्त प्रथम  
इंगानप, बीकानेर।