

OFFICE OF THE EXECUTIVE ENGINEER PWD DISTT. DN-I, BIKANER

No : 4006

Dated : 13/11/18

To

The Executive Engineer (T&C),
R.R.V.P.N.L., Bikaner.


Sub : - 'NOC' for the SH-03 Road Over head crossing by laying of 220 KV D/C.
Gajner Chattargarh transmission Line. 207/0 to 208/0

Ref : - Your office letter No.1070 DT 12.11.2018

Sir,

With reference to the subject cited above, it is submitted that this office has no objection to cross/ pass over the SH-03 road in between KM stone 208 & 207 by laying of 220 KV D/C. Gajner Chattargarh Transmission Line. The RRVPNL Bikaner authority may please be directed to ensure safety of road traffic at the time of laying of Transmission line on priority basis. No pole should be erected in road way width, distance of tower from road ^{centre} is 165 & 125 mtr.

Yours Sincerely,


13.11.2018

(Laxman Singh)

Executive Engineer
PWD Distt. Dn-I, Bikaner