

DETAIL NOTE ON PROJECT

BRIEF DETAIL OF 132 KV D/C CHHATARPUR - JAPLA TRANSMISSION LINE BEING CONSTRUCTED BY JHARKHAND URJA SANCHARAN NIGAM LIMITED (JUSNL).

The government of India has identified the power sector as a key sector of focus to promote sustained industrial growth. It has embarked on an ambitious mission - "Power for all" backed by extensive reforms to make the power available to each household. JUSNL is fully committed to provide uninterrupted Power supply to each village by strengthening the grid and connectivity between them.

With this view, JUSNL is developing a transmission line 132 Kv D/C Chhatarpur - Japla Transmission Line. line length of 35.660 Km is passing through Chhatarpur, Husenabad and Pipra block of Palamu District. Total no. of villages -10 are involved in the project. Since this is a linear project, hence gram sabha consent is not required in the project nor environment clearance is required.

Transmission line projects are environmentally friendly and do not involve any disposal of solid effluents and hazardous substances in land, air and water. The constructional features of 132KV D/C line is such that it is not affecting the environment as it's not dividing the existing forest because of long spans between the towers (320 Mtrs). Layout of transmission line follows along the forest road / forest block boundary thus involving minimum tree felling and also allowing free movement of birds and cattles due to high ground clearance of lower most conductors which is 6.1 meters. The spacing between the phase conductors is maintained as per guidelines which makes the free movement of birds as well. A very small space is required for the construction of tower foundations (10 X 10 Mtrs). The tower foundations are under the ground (3 Mtrs) and a small portion of 0.50 X 0.50 Mtrs are elevated as plinth. There is also no muck disposal in transmission line as the excavated soil will be filled back and compacted. For the construction of line, as per telegraph act 1885 and electricity act 2003, land is not acquired. The land ownership on which the tower is constructed will be unchanged and will remain in original owner name.

The 132 Kv D/C Chhatarpur - Japla Transmission Line starting from Village – Rudwa to Village - Panchaba. It will create the employment opportunity for local villagers during the construction phase (18 Months) and later on for maintenance of Transmission line, hence affecting the life of village people directly. In indirect as the project is to strengthen the power system in Palamu District, hence would encourage industries in the region resulting employment opportunity.


SENIOR MANAGER
TRANSMISSION DIVISION
DALTONGANJ

TRANSMISSIONLINEDETAILS:-**132 KV D/C CHHATARPUR - JAPLA TRANSMISSION LINE**

Sr. No.	Item	Details
1	132 Kv D/C Chhatarpur - Japla Transmission Line	TotalLineLength:35.660Km
2	Total No of Towers to be erected	Total towers: 120 Nos.
3	District details and forest division details through which line is passing	District: Palamu (Block – Chhatarpur, Husenabad and Pipra) Forest Division: Medininagar
4	Area of the Protected forest through which line passes.	Medininagar Forest Division -23.2676 Ha
5	Total No. of Tower to be erected in Forest area in Latehar.	Affected towers in Forest area-22 Nos.
6	Ground clearance of lowest conductor of line	6.1mtrs
7	Maximum width of Right of Way for 132 KV D/C Transmission Line	27Meters (As per MoEF Guideline dated 5 th May 2014)
8	Width below each conductor for which tree felling is permitted	3 mtr below each conductor.
8	Minimum Clearance allowed between conductors of transmission lines and Trees	For132KV,4Meters.


**SENIOR MANAGER
TRANSMISSION DIVISION
DALTONGANJ**