



(H.P. Govt. Energy Development Agency)
HIMURJA, Urja Bhawan SDA Complex Kasumpti Shimla-171009
PHONE-177-2620365,2621783, 2625306,2621623. FAX 177-2622635

No. HIMURJA/SHP/Bithari (MME)/2014- 3257 Dated 09-04-2015
To

M/s Mani Mahesh Enterprises.,
123/6 Samkhetar, Mandi. H.P.
Pin-175001

Subject :- Consent for exclusive time-bound right for preparation of Project Report for the Small Hydel Project Bithari (0.40 MW) in Distt. Mandi, Himachal Pradesh.- Submission of feasibility report of 0.40 MW capacity

Dear Sir,

This is in reference to your letter No. MME/2014-102 dated 09/03/2015 vide which Feasibility Report in respect of Bithari SHEP in District Mandi has been submitted to Himurja. After examining the Feasibility Report the parameters are frozen as under:

Sr. No.	Name of Project	River/ Stream	District	Elevation Range (Diversion to Tail race)	Capacity	Tentative Land Required	
						Forest	Private
i	Bithari	Pangna	Mandi	Weir -1746m PH -1661.50m Tail - 1660m	0.40MW	1.64 Ha	0.20 Ha.

It is further stated that the approval of the Feasibility Report (FR) of Bithari SHEP in District Mandi shall be subject to the following conditions:-

1. There shall be no change in the elevations from the elevation freezes in the FR.
2. Discharge data has to be observed for optimization of capacity in the DPR, if it varies from the figure of Feasibility Report, Technical Concurrence is required to be obtained from DoE.
3. Evacuation point has to be got finalized from HPSEBL/HPPTCL.
4. Elevations of each component must be marked in the location plan and should also be included in the salient feature.

Therefore, you may go ahead for obtaining various clearances/NOCs on the basis of parameters frozen herein above. It is further intimated that submission of FR was delayed by one months from the stipulated period. It is therefore requested to deposit the extension charges amounting to Rs. 4,000/- through Draft in favour of Director Himurja payable at Shimla within 21 days.

Yours Sincerely,

Director,

HIMURJA, Urja Bhawan,
Kasumpti-Shimla-171009.