



H.P. Power Transmission Corporation Limited
(A State Govt. Undertaking)
Barowalias House, Khalini, Shimla-171002
(Telefax: 0177-2626284)

NO. HPPTCL/TEC-Vol-IV/2015-3113-15

Dated:- 24/8/2015

To.

✓
M/S Manimahesh Enterprises,
123/6, 1st and 2nd Floor,
Samkhetar, Mandi-175001

Subject: - Evacuation arrangement for Bithri SHP (0.4 MW).

Sir:

With reference to your letter No. DHPPTCL—01-04-2015 dated 30.4.2015, it is to intimate that power of Bithri SHEP can be evacuated by constructing 0.6 Kms long 22 kV HT line from Bithri SHP to existing 22 kV HT line at Bithri village by solid tap. Reconductoring of 22 kV HT line about 2.42 Km along with auto reclosure and other equipments required for interconnection shall be borne by the IPP and no deemed generation shall be allowed.

Yours Faithfully,


General Manager (C & D)

Copy to:

1. Chief Engineer (SO & P), HPSEBL, Vidyut Bhawan, Kumar House, Shimla-171004. w.r.t his letter No. HPSEBL/ CE (SO & P)/PH & T/DB-65 (A) (NP) Vol-IV/2015-3089-90 dated 17.8.2015 for information and necessary action please.
2. Chief Engineer, Energy Directorate, Shanti Bhawan, Phase-III, Sector-6, New Shimla-171009 for information and necessary action please.


General Manager (C & D)