

I/11101/2020



भारत सरकार
Government of India
 विद्युत मंत्रालय
Ministry of Power
 केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
 विद्युत प्रणाली योजना एवं मूल्यांकन-I प्रभाग
Power System Planning & Appraisal-I Division

सेवा में / To,

Rajesh Kumar Gupta,
 Deputy General Manager,
 Adani Green Energy Ltd,
 Adani Corporate House,
 Shantigram, S G Highway,
 Ahmedabad, 382421.

विषय : विद्युत अधिनियम, 2003 की धारा 68(1) के तहत M/s Adani Green Energy Limited को पारेषण योजना “Connectivity to M/s Adani Green Energy Limited for its proposed 300 MW wind farms in Bhuj, Gujarat” के लिये भारत सरकार का पूर्व अनुमोदन – सम्बंधित

Sub: Prior approval of the Government of India under section 68(1) of the Electricity Act, 2003 to M/s Adani Green Energy Limited for the transmission scheme “Connectivity to M/s Adani Green Energy Limited for its proposed 300 MW wind farms in Bhuj, Gujarat” - reg.

संदर्भ / Reference:

- (i) M/s Adani Green Energy Limited letter no. AGEL/SECI-V/CEA/section-68/02 dated 13.08.2020.
- (ii) M/s Adani Green Energy Limited email dated 19.08.2020.
- (iii) M/s Adani Green Energy Limited letter no. AGEL/SECI-V/CEA/section-68/03 dated 25.08.2020.

महोदय / Sir,

M/s Adani Green Energy Limited (AGEL) vide its letters under reference has sought prior approval of the Government of India under section 68 (1) of the Electricity Act, 2003 for the transmission scheme “Connectivity to M/s Adani Green Energy Limited for its proposed 300 MW wind farms in Bhuj, Gujarat” with the following scope of work:

- (i) Adani Green Energy Limited (PSS-1 in the vicinity of village Narayanpar, Tehsil-Kutch, District-Bhuj) - Bhuj-II PS 220 kV S/c line (On M/c towers) along with associated bays at generation end.

I/11101/2020

- (ii) Adani Green Energy Limited (PSS-2 in the vicinity of village Vayat, Tehsil-Kutch, District-Bhuj, Gujarat) - Adani Green Energy Limited (PSS-1) 220 kV S/c line (on D/c towers) along with associated line bays at both end.
2. The above transmission scheme has been discussed and agreed in 32nd meeting of WR Constituents regarding Connectivity and LTA applications held on 26.11.2018.
3. CEA conveys the prior approval of Government under Section 68(1) of Electricity Act, 2003 to M/s AGEL for the following overhead lines covered under the transmission scheme "Connectivity to M/s Adani Green Energy Limited for its proposed 300 MW wind farms in Bhuj, Gujarat":
- (i) Adani Green Energy Limited (PSS-1 in the vicinity of village Narayanpar, Tehsil-Kutch, District-Bhuj) - Bhuj-II PS 220 kV S/c line (AL59 Zebra conductor) on M/c towers.
Line length is approx. 17 kms.
- (ii) Adani Green Energy Limited (PSS-2 in the vicinity of village Vayat, Tehsil-Kutch, District-Bhuj, Gujarat) - Adani Green Energy Limited (PSS-1) 220 kV S/c line (AL59 Zebra conductor) on D/c line.
Line length is approx. 58 kms.
4. This approval is subject to compliance of
- The relevant provisions of the Act, as amended from time to time and the rules and regulations made there under, and
 - CEA (Measures relating to Safety and Electrical Supply) Regulations, 2010 and any subsequent amendments made thereto.
5. The approval is also subject to the following conditions:
- The implementing agency will commence construction of the project within three years of grant of approval, unless this term is extended by the Central Electricity Authority.
 - Central Electricity Authority may withdraw the approval before the expiry of the period of three years after giving a one-month notice.
 - The implementing agencies shall abide by the provisions of Works of Licensee Rules, 2006 notified by the Govt. of India, Ministry of Power in the Gazette of India, extra-ordinary Part-II, Section 3(i) dated 18-04-2006 (vide GSR 217 (E) dated 18-04-2006).

भवदीय / Yours faithfully,

(पी. सी. कुरील / P.C. Kureel)

सचिव, के.वि.प्रा / Secretary, CEA

प्रति लिपि / Copy to -

- (i) Joint Secretary (Trans), Ministry of Power, Shram Shakti Bhawan, New Delhi.