

## RECOMMENDATION

The diversion of forest land proposed for 11 KV electric feeder line from Gayarkata sub station to Khutimari Forest Rest House under Moraghat Range for village electricity under Din Dayal Upadhaya, Gram Jyoti Yojana under proposal no. FP/WB/VELEC/34640/2018 is barest minimum and is unavoidable. The total land proposed for diversion is only 0.90 ha (2mX 4500m) and will not have any negative effect on forest soil and wildlife if insulated wire is used above 6m above the ground.

Hence the case is recommended.

  
08/06/2019.  
(G.P.Chhetri, IFS)  
Chief Conservator of Forests,  
Northern Circle, West Bengal