


## Site Inspection Report

I have inspected the proposed site for the Diversion of 1.2411 Ha. of forest land in Sy.No. 198, 199 & 214 of Hebri village, Ajekar hobli, Karkala Taluk Udupi District for laying of 11KV/HT Express line from Hebri MUSS to Varanga passing through Jaravathu kadu RF and along the PWD road in favour of the Executive Engineer (Ele), O&M Division, Mangalore Electricity supply Limited (MESCOM), Udupi on 16-04-2021.

The proposed area for the purpose of laying of 11 KV/HT Express line from Hebri MUSS to Varanga passing through Jaravathu Kadu RF and along PWD road. User Agency has asked for 7 Mtr width corridor, with line passing through the Jaravathu Kadu RF and along the PWD road. The alignment is proposed in such a way that no trees will be cut and only branches will be trimmed to pass the AB covered conductor cable.

The requirement of Reserve forest area as proposed by the User Agency in 1.2411Ha. It is found that 147 trees are present in the area proposed for diversion but User Agency has stated that the proposed work does not require cutting down any trees.

The User Agency has to pay the NPV and also has to bear the cost of raising of CA plantation. Hence, the proposal may be considered for clearance under Forest (Conservation) Act 1980 with recommendation of laying of 11 KV/HT Express line by installing AB covered conductor cable.



Chief Conservator of Forests,  
Mangaluru Circle, Mangaluru.

Date: 19.04.2021

Place: Mangaluru