

PART-III
(To be filled by the concerned Chief Conservator of Forests)

14	Whether site, where the forest land involved is located has been inspected by concerned Chief Conservator of Forests (Yes/No). If yes, the date of inspection & observation made in form of inspection note to be enclosed.	No
15	Whether the concerned Chief Conservator of Forests agree with the information given in Part-B and the recommendation of Deputy Conservator of Forests.	Yes
16	Specific recommendation of concerned Chief Conservator of Forests for acceptance or otherwise of the proposal with detailed reasons.	Yes, the proposal is recommended for 0.0315 ha. reserved forest area with following conditions : 1. The electric wire which passes through the forest area to be insulated. 2. Appropriate care should be taken to avoid sparkling. 3. The transformer establishment should be properly covered to avoid any wildlife electrocution 4. Any losses due to electric accident is the responsibility of the user agency and suitably compensated by them. 5. Before regular maintenance pruning of branches, permission from the forest department to be obtained. 6. The Purpose (Agriculture) for which the electric connection is demanded should be adhered. 7. As the safari park Forest area is nearby their should not be any disturbance to the wildlife by high intensity light in the Agriculture area. 8. If the purpose, for which electric connection is sought, is changed, the PGVCL should take immediate legal action on the owner and take appropriate steps to monitor the use of electricity other than the purpose sought.

Date : 19 /02/2019
Place : Junagadh.


[D. T. Vasavada]
Chief Conservator of Forests,
Wildlife Circle, Junagadh.