

### PART – III

**Diversion of 0.12 hac. of forest land for erection of 11KV Transmission Line/feeder to  
udyog kunj Industrial Area, HSIIDC along Gurgaon-Alwar Road at Village Alipur, Tehsil  
Sohna under Forest Division and Distt. Gurugram**

14)	Whether site, where the forest land involved is located has been inspected by concerned Conservator of Forests (Yes/No). If yes, the date of inspection & observations made in form of inspection note to be enclosed.	No
15)	Whether the concerned Conservator of Forests agree with the information given in Part-B and the recommendations of Deputy Conservator of Forests.	Yes
16)	Specific recommendation of concerned Conservator of Forests for acceptance or otherwise of the proposal with detailed reasons.	As per guidelines issued under FC, Act 1980 and subsequent MoEF letter no. F.No. 7-25/2012-FC dated 05-05-2014 ROW for 11KV is 7.0meter. However, keeping the view of public importance and minimum usage of forest land, case for diversion of 30cm wide strip of forest land as proposed by user agency and forwarded after scrutiny by competent authority, the case is recommended for approval

Place: Gurgaon

Dated: 18-01-2017

  
**Conservator of Forests,  
South Circle, Gurugram**