

Part – III

(To be filled by the concerned Conservator of Forests)

14. Whether site, where the forest land involved is located has been inspected by Concerned Conservator of Forests (Yes/No). If yes, the date of inspection & observations made in from of inspection note to be enclosed : Yes.
16-03-2017
Site inspection report attached.
15. Whether the concerned Conservator of Forests agree with the information given in Part – B and the recommendations of Deputy Conservator of Forests : No
16. Specific recommendation of concerned Conservator of Forests for acceptance of otherwise of the proposal with detailed reasons : Inspected the site on 16-03-2017. The proposal is for laying LT single phase 2 wire line and provide service connection to Shri. Samad.K.V. under Total electrification Scheme. Area to be diverted for drawing electric line is 0.07 ha. The area is having young acacia plantation. Tree felling and lopping is to be carried out if line is drawn as proposed. It is therefore recommended that user agency should plan for laying UG cable instead of overhead line. The project in the present form is therefore rejected

Date: 18-03-2017

Place : Kollam

Signature : 

Name : Deepak Mishra IFS

Official Seal :

Chief Conservator of Forests, (SC),
Kollam.