

Letter No.....45.....

Dated 25-01-2019

From,

Electrical Executive Engineer  
Jharkhand Urja Sancharan Nigam Ltd. (JUSNL)  
Transmission Division, Chaibasa

To

The DFO ,  
Saranda Forest Division,  
Chaibasa.

**Subject: Regarding 51.266 Ha Forest diversion case under FCA 1980 out of which 9.118 Ha forest land in Saranda forest division, online proposal.**

Dear Sir,

Your letter no 04/chaibasa, dated 02/01/2019 in which you have enquired for few quarries .Serial wise reply of the quarries are as follows.

1. Our transmission line not passing through National park, Wild life sanctuaries and elephant corridor. Elephant corridor is even 13 km away from transmission line nearest corridor.

In future if any plan suggested by your department or state Govt. it will be welcomed from our end.

2. For protecting bird hitting bird guard is erecting in our transmission line as per norms.

3. All the towers traversing in saranda forest area will be covered by fencing wire or as per forest norms.

Sir our conductor(ACSR Zebra) is bared but it is insulated by disc insulator hence there is no scope of electrocution of animals.

**We would like to request you please manage to upload the proposal from your end As soon as possible so that proposal could go ahead.**

Yours faithfully,

*Saelaw*  
25.01.19

Electrical Executive Engineer  
Transmission Division, Chaibasa