



INDRAPRASTHA GAS LIMITED


(A Joint Venture of GAIL(India) Ltd, BPCL & Govt. of NCT of Delhi)

Undertaking about NOC of NHAI

Subject: Proposal for seeking permission to use the 0.99 ha. Protected Forest Land for non-forestry purpose for laying of (300mm) Carbon Steel Gas Pipeline along NH-19 (Kanpur - Prayagraj Section) on L.H.S. from Km. Ch. 519.000 to Km. Ch. 552.000 (Length 33.00 Km) in District-Fatehpur by Indraprastha Gas Limited, New Delhi.

It is to certified that we have applied for getting NOC of concern land owner department NHAI and it is in process by NHAI Regional Office- West UP, Lucknow letter no. 19001/1/RO-W-UP/NH-19/Km 486 to Km 552/UG/528 Dated 14.12.2020. (Copy Enclosed).

It is hereby undertaking to submit the NOC with the hard copy of Proposal whenever issued by NHAI.



RAMAN KUMAR SRIVASTAVA
Chief General Manager (GA Head)
INDRAPRASTHA GAS LIMITED
Kanpur (Part), Fatehpur & Hamirpur
808-810, 8th Floor, 14/113, Kan Chamber
Civil Lines, Kanpur-208001



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)

क्षेत्रीय कार्यालय-पश्चिम उ०प्र०, लखनऊ

Regional Office - West UP, Lucknow.

3/248, विशाल खण्ड, गोमती नगर, लखनऊ-226010 (उ.प्र.)

3/248, Vishal Khand, Gomti Nagar, Lucknow-226010 (UP)

दूरभाष / Phone : 0522-4960291

टेलीफैक्स / Fax : 0522-4950680

ई-मेल / E-mail : rowestup@nhai.org

rowestup@gmail.com

वेबसाइट / Website : www.nhai.gov.in

19001/1/RO-W-UP/NH-19/Km. 486 to Km 552/UG/ 528.

Dated: 14.12.2020

Invitation of Public Comments

Sub: Permission for laying of underground Gas Pipeline (300mm CS Dia STEEL Pipe) by HDD/ Trenching method along NH-19 (Kanpur-Prayagraj) between Ch. 486.00 to Ch. 552.00 (LHS) in District-Fatehpur in the State of Uttar Pradesh.

The Chief General Manager (GA Head) M/s Indraprastha Gas Ltd., New Delhi has submitted the proposal for permission for laying of underground Gas Pipeline (300mm CS Dia STEEL Pipe) by HDD/ Trenching method along NH-19 (Kanpur-Prayagraj) between Ch. 486.00 to Ch. 552.00 (LHS) in District-Fatehpur in the State of Uttar Pradesh.

2. From the submitted proposal, it is seen that the crossing length is proposed 66000 Mtrs. on LHS from the location of Kulganv Mod (Km. 486.00) to Lalganj Bypass (Km. 552.00) on NH-2 (New NH-19). Depth of the utility service from ground level is proposed 1.5m. The laying work along the highway will be done by Trenching/Open Cut Method, only crossing of NH/Culverts/Drains/Canals/Rivers/Market Areas/Villages and Cities connecting Roads will be executed through HDD Method. In this regard, M/s Indraprastha Gas Ltd. has undertaken that they will ensure all safety measures and will confirm all standard condition of NHAI/MoRT&H Guidelines.

3. As per the guidelines, issued by the Ministry vide OM No.RW/NH-33044/29/ 2015/ S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

4. In view of the above, comments of the public on the above application is invited to the below mentioned address, which should reach by this office within 30 days from the date of publication beyond which no comments shall be entertained.

The General Manager cum Regional Officer,
National Highways Authority of India
Regional Office, UP-West, Lucknow
3/248, Vishal Khand, Gomti Nagar
Lucknow-226 010

This issues with the approval of RO-West (UP).

Encl: As above.

(Roopak Jain)
Dy. Manager (T)
For RO-UP (West)

Copy to:

1. Web Admin, NHAI-HQ- with request for uploading on the NHAI website.
2. The Technical Director, NIC, Transport Bhawan, New Delhi- with request for uploading on the Ministry's website.
3. CGM (GA Head) M/s Indraprastha Gas Ltd., New Delhi.
4. PD, PIU-Kanpur with request to submit the compliance of this office letter No. 527 dt. 14.12.2020 for taking further necessary action on the proposal.

"Building a nation, not just Roads."