

SOUTH DELHI MUNICIPAL CORPORATION
OFFICE OF THE EXECUTIVE ENGINEER (M-IV) NGZ
ROOM NO. 507, 5th FLOOR, ZONAL OFFICE BUILDING,
DHANSA STAND, NAJAFGARH, DELHI-110043
e-mail : eeemivngzsdmc@gmail.com

No.EE(M-IV)NGZ/2020-21/D-1295

Dated : 22/01/2021

To,

The Chief Manager,
Power Grid Khetri Transmission System Ltd.
765/400 KV Jhatikara Sub-Station, Vill.- Gummanhera & Shikarpur
Najafgarh, Delhi


Subject: Construction of 765 KV D/C Khetri-Jhatikara Transmission line – Proposal for NOC of road crossing.

Reference: Your office letter No: NR1/JTKR/TLC/765KV Khetri-Jhatikara/Forest/MCD/869
Dated:25.07.20

On the subject referred above, the permission of road crossing on the following roads at height as per I.E.R.(Indian Electricity Rule) is hereby accorded with the condition that during the construction of transmission line proper barricading and safety measurement should be followed.

Sr. No	Name of road	Crossing Tower No	Clearance	Nearby village
1	Shikarpur to Ghummanhera road	AP-4/0 to AP-4A/0	18.00 M	Shikarpur
2	Daurala to Badsa Road	Loc. No.-15/1 to AP-16/0	25.50 M	Daurala

DA/Nil


E.E.(M-IV)-NGZ/SDMC
M. P. PANWAR
Executive Engineer (M-IV)
Najafgarh Zone/SDMC