

**Himachal Pradesh --IPH Department**

NO.IPH-IDK-II-WA-NOC/2019:-  
To

1935-32

Dated:- 14/08/2019

The Superintending Engineer  
IPH Circle Kullu

Subject: -

Issue of No Objection Certificate for construction of Choj-1 Small Hydro Project (0.50MW ) ( Manikaran Area) in Distt. Kullu HP.

M/s Tek Singh, V.P.O. Shiah Tehsil Bhunter Distt. Kullu HP  
Vide his letter No. Nil dated Nil has intimated that 0.50 MW Choj-1 Small Hydro Project Vill. Choj P.O. Manikaran Tehsil Bhunter Distt. Kullu H.P. has been allotted to for which NOC has been required for this Project

In this a connection it is submitted that this Department has no objection for C/O this project as there exists no WSS/ LWSS/LIS FIS on down / upstream of proposed project presently . The case is recommended for its NOC subject to condition as below:-

- 1 The Firm shall enter into legal agreement with the Department in this respect.
- 2 That the Chief Engineer (MZ) IPH Department, Mandi shall be the sole adjudicator of any dispute arising during construction as well as subsequently and his decision shall be binding on all the parties.
- 3 In case there is any scarcity of water due to the drought or any reasons, the requirement of department shall have precedence over the requirement of this Hydro Power Project.
- 4 The firm shall ensure adequate minimum environment flow in river/ Khad below the diversion site to take care of aquatic life and ecology of the area. However, the minimum flow shall not be less than 15% of the available discharge at any time in the river.
- 5 The firm shall rehabilitate/repair/compensate for IPH Deptt. Assets/water resources as well as private kuhals/Irrigation schemes/water supply schemes in case these are... damaged or adversely affected due to construction/operation of the project. During restoration period the arrangement for providing of water to the beneficiaries shall be made through tankers and other alternative possible arrangements by the firm.
- 6 Additional requirement of water of the department in future in addition to the project demand will get priority over the water requirement of the firm.

7. In addition to I&PH Department requirement, the firm will also satisfy the requirement of private users, if any.
8. The Department will have liberty to draw water from Gohar Nallaha a tributary of Partvati river (Upstream and downstream) for construction of any water supply on up and down stream of the HEP if any scheme get effected i.e. irrigation or water supply as and when required is future. The executing agency will have to deposit the original cost of scheme/cost of its remodeling with the department in advance so as to make these facilities available to inhabitants of affected area for which the company will have no objection.
9. The present and future quantity of water for proposed WSS will be tapped by the department from Gohar Nallaha a tributary of Partvati river up-stream of the intake of the HEP and the department will have precedence over the requirement of the proposed project.

The following documents as received from firm/company are sent herewith for further action please.

DA:- As above

Executive Engineer  
IPH Division No.II  
Kullu at Bhunter.

Copy to the Assistant Engineer IPH Sub Division Shat w.r.t. to his office letter No.13-14 dated 24.04.2019 for information.

Copy to the M/s Tek Singh, V.P.O. Shiah, Tehsil Bhunter Distt. Kullu HP 175105, H.P. for information.

Copy to the Project Officer Himurja Kullu Tehsil & Distt. Kullu for information.

Executive Engineer  
IPH Division No.II  
Kullu at Bhunter