

CREDIT LT POLE SCHEDULE									
Location	Span Length	Psc Pole 8.0 mtr	LT 3 Ph. X arm	Back Clamp 8.0Mtr	LT Shackle WMP	LT Pin Insulator	Aluminium Knob	ACSR 7/3.35 for LT	ACSR 7/2.59 for LT
SS			1	1	3		1		
H2	18		1	1	3		1	54	18
D1	33		1	1	3		1	99	33
D2	33		1	1		3	1	99	33
D3	34		1	1		3	1	102	34
D4	33		1	1		3	1	99	33
D5	35		1	1		3	1	105	35
D6	36		1	1	3		1	108	36
D7	65	1	1	1		3	1		260
D8	65	1	1	1		3	1		260
D9	70	1	1	1	6		1		280
D10	80	1	1	1		3	1		320
D11	65	1	1	1		3	1		260
D12	70	1	1	1	3		1		280
D13	55	1	1	1		3	1		220
D14	30		1	1	3		1		120
H3		1							
H4		1							
H5		1							
H6		1							
D15-16						6			
TOTAL	722	11	16	16	24	33	16	666	2222

Sd /xxxx/28.10.17
 Superintending Engineer
 Dindigul
 Electricity Distribution Circle
 TANGEDCO DINDIGUL-2

FORWARDED / BY ORDER


 AEE / PRO & DEV, DEDC
 DINDIGUL