

CIN - U40108CT2003SGC015820

CHHATTISGARH STATE POWER TRANSMISSION COMPANY LIMITED
(A GOVERNMENT OF CHHATTISGARH UNDERTAKING)

O/o EXECUTIVE ENGINEER EHT CONST. DN, CSPTCL, TIFRA, BILASPUR
Email Address: eeeh.t.bilaspur@cspc.co.in Ph. No. / Fax 07752-427074

NO. /EE/EHT:C/Dn./Wks / 1903,

BILASPUR, DATE: 28.02.2020

To,

The Principal Chief Conservator of Forest
Aranya Bhawan, sector 19 ,
Atal Nagar Raipur

Subject:- Diversion of 7.011 hectare of forest land for non-forest work in Raigarh forest division for construction of 132 KV D/C Gerwani to Korrichhapar (TSS) Line by Chhattisgarh State Power Transmission Company Limited in District Raigarh of Chhattisgarh State.

Reference: EDS Raised on dated 19/02/2020 with letter No.- 115-854/2020 on Parivesh Portal from your good office.

Proposal No.- FP/TRANS/CG/44321/2020

As per cited subject ,compliance of observations has been made ,the details which are as here :

Sr. No.	Query	Compliance
1	In point B-1, Upload details of proposal submitted in past	Details of Proposal submitted in past has been uploaded
2	In Point B-2.4, Upload component Breakup wise details	Correction has been made
3	C.(ii) b(1): Upload KML with attribute having following (RF/PF along with compartment no. and area in ha./ Revenue Forest Land along with Khasra no. and area in ha.) details and upload polygon for all Forest and Non forest land.	Correction has been made
4	In polygon attribute total area is showing 108.69 ha, but in point A-1 (viii and ix) total forest-7.011+ non forest-102.663= 109.624 ha that is not matching with showing polygon area. On Non-Forest land 132 KV D/C Gerwani to	Polygon with attribute of total following details for land 109.624 has been uploaded Small voltage transmission line can be constructed under 765 KV Extra High Voltage (EHV) T/L because EHV having the tower height 65-

	Korichhapar (TSS) Line is passing under the Power Grid Corporation of India Limited - Construction of 765 KV D/C Jharsuguda - Dharamjaygarh 2 nd Transmission line, Explain	70 meter and 132 KV T/L having height of 25-30 meter
5	Additional Information i. Upload/Attach DGPS Report duly signed by DCF/DFO ii. Upload forest area statement iii. Upload Approval letter of Government of India for the above work	Additional Documents has been uploaded


 EXECUTIVE ENGINEER
 EHT CONST. DN CSPTCL BILASPUR

Copy to:

1)The Divisional Forest Officer Raigarh (C.G.)