



OFFICE OF THE CHIEF ENGINEER (Barmer-Zone)
JODHPUR VIDYUT VITRAN NIGAM LIMITED, BARMER

CIN NO. : U40109RJ2000SGC016483

Registered Office – New Power House, Jodhpur

Phone : 220640-02982 Fax : 02982 & 220573,

Email : cebmrzone@gmail.com

No: JdVVNL/CE/Bmr-Z./Tech./2020-21/D 3116

Barmer, Dated 24/03/2021

The Superintending Engineer (O&M)
 Jodhpur Discom, Jaisalmer.

Sub: Technical Sanction for erection of new 33 KV line (25.77 KM) required for releasing of new connection as applied by HPCL-Rajasthan Refinery Ltd. (HRRL) having CD-5400 KVA (at 33 KV voltage level), from 400 KV Bhadla to HRRL water pumping facility site near Nachana Phata KhNo. 4061,4062,4220/4445,4210 under AEN (O&M), JdVVNL, Nachana.

Ref: (i) AS letter No. 3689 dt. 18.03.21 of SE(PP&M), JdVVNL, Jodhpur .
 (ii) Your office letter No. 2894 Dtd 01.03.21 & 2772 Dtd 16.02.21

Technical Sanction for erection of 33 KV line (25.77 KM) required for releasing of new connection as applied by HPCL-Rajasthan Refinery Ltd. (HRRL) having CD-5400 KVA (at 33 KV voltage level), from 400 KV Bhadla GSS to HRRL water pumping facility site near Nachana under AEN (O&M), JdVVNL, Nachana is hereby accorded under D.O.P. Item No. 1(a) as below:

S.No	Particulars of works	Estimated cost (In Rs.)	Chargeable Head
(A)	Erection of 33KV O/H line S/C line 25.77 KM from 400 KV Bhadla GSS to HRRL water pumping facility site near Nachana Phata (with 60 Meter (1+1) 33 KV U/G cable in 400 KV Bhadla GSS and check meter at applicant premises on applicant request)	3,60,33,984.00	Deposit Head- Deposit by HPCL- Rajasthan Refinery Ltd.
(B)	Erection of associated metering equipment at 400 KV Bhadla GSS	2,47,248.00	
TOTAL		3,62,81,232.00	

The sanction of the above work is hereby accorded subject to the following terms and conditions.

1. All terms and condition laid down in letter number 3689 dt 18.3.21 of the SE (PP&M), JdVVNL, Jodhpur Discom, Jodhpur be followed strictly.
2. All codal formalities may be got completed before starting the work as per the Nigam rules
3. All the rules and regulation prevailing in discom regarding the above works must be strictly observed and compiled too.
4. Undertaking should be obtained from applicant that during Audit or other reason if estimated amount is change applicant will be agree to deposit the difference amount.

Chief Engineer (BMR-Z)
Jodhpur Discom: Barmer.

Copy forwarded to the following for information and necessary action

1. The Executive Engineer (O&M) JDVVNL, Pokaran
2. The Account Officer (O&M) JdVVNL, Jaisalmer.
3. The Assistant Engineer (O&M) JDVVNL, Nachana.

OFFICE OF THE CHIEF ENGINEER (O&M)
Jd.V.V.N.L. Jaisalmer

R.R.No. 75 Date 7/4/21

1. TA
2. Tech.
3. Works
4. Giv.
5. Rev.
6. Estt.
7. p.o.
8. Legal
9. F.M.
10.

TA

SE

054
06/04/2021

Copy to AEN (O&M) Nachana for information & necessary action.

7.4.2021.

Chief Engineer (BMR-Z)
Jodhpur Discom: Barmer

OFFICE OF THE SUPERINTENDING ENGINEER (O&M)
JODHPUR VIDHYUT VITRAN NIGAM LIMITED, JAISALMER

No: JdVVNL/SE (O&M)/Jsm./2020-21/D.4809 Jaisalmer, Dated 19.01-2021

The Zonal Chief Engineer (BMR-Z)
Jodhpur Discom, Barmer

515
27-01-21

Sub: Submission of Estimate for technical & admn. Sanction for release of connection for HPCL Rajasthan Refinery Ltd. connection at Nachana under AEN (O&M), JdVVNL, Nachana.


Ref: Letter No. 650 dt 11.1.2021 of the XEN (O&M), JdVVNL, Pokaran.

On the above cited subject, kindly find enclosed herewith estimate / proposal of release of connection for HPCL Rajasthan Refinery Ltd. connection at Nachana for technical and admn sanction under AEN (O&M), JdVVNL, Nachana as received from the Executive Engineer (O&M), JdVVNL, Pokaran vide letter as under reference. As details here under:

S. No.	Name of Applicant	Particulars of work	Qty./Unit	Total
1	HPCL Rajasthan Refinery Ltd., Kh No. 4061, 4062 & 4066	33 KV Line	25.77 KM	36370790.00
2	Nachna Fanta	33 KV Metering	1 No.	312100.00
3		T/F provided by applicant/Party		0.0
TOTAL				36682890.00


Therefore, requested to kindly convey the necessary administrative & technical sanction as per DOP for the above works at an earliest.

Encl: Original case of file.


Superintending Engineer (O&M)
Jodhpur Discom: Jaisalmer

Copy forwarded to the following for information & necessary action

1. The Executive Engineer (O&M), JdVVNL, Pokaran.
2. The Assistant Engineer (O&M), JdVVNL, Nachana.


Superintending Engineer (O&M)
Jodhpur Discom: Jaisalmer

CC
Jsm
A. D.