Corporate Identity Number (CIN) -U40109RJ2000 SGC015483 Regd. Office: New Power House, Jodhpur- 342003

Phone No: 0291-2746255

E-mail: seppmju@gmail.com Web site: www.jdvvnl.com

No. JdVVNL/SE(PPM)/ The Chief Engineer (B-Z),

D. 3689

Dated 18/3/2/

Olodhpur Discom,

Barmer.

Sub:- Administrative sanction for erection of new 33 KV line required for releasing of new connection as applied by HPCL-Rajasthan Refinery Ltd. (HRRL) having CD-5400 KVA (At 33 KV voltage level), 33 KV line length 25.77 KM overhead line from 400 KV Bhadla to HRRL water pumping facility site near Nachana phata Kh No. 4061, 4062, 4220/4445,4210 under AEN (0&M), Nachna Dist -Jaisalmer, under deposit work.

Ref: Your office letter no. 2772 date 16.02.21.

Based on the recommendation as received vide office letter referred above, administrative clearance to carry out following 33 KV works is here by accorded as under.

S.no.	Particular Particular	Est. cost of work
1.	Erection of new 33KV O/H line S/C 25.77 KM from 400 KV Bhadla GSS to HRRL water pumping site near Nachna Phata. (with 60 meter (1+1) 33 KV cable in 400 KV Bhadla GSS and check meter at applicant premises on applicant request)	3,60,33,984.00
2.	Erection of associated metering equipment at 400 KV Bhadla GSS	2,47,248.00
	Total (1)+(2)	3,62,81,232.00

ollowing terms & condition may please be adhered to at each & every stage.

All codel formalities as per erstwhile RSEB / Nigam rules & regulation.

Prior to start of the work, necessary charges are to be got deposited from applicant. Since estimates are tentative therefore if any revision in price/minor changes in estimate, then actual charges along with overhead charges are to be deposited by applicant.

Prior to start of the work, please ensure line length of 33 KV line works according to the actual

Complete work would be carried out under the supervision of Engineer nominated by Superintending Engjreer (O&M), JdVVNL, Jaisalmer.

After final execution of work, MAS be prepared and if any deviation of material account is found, issue additional DN of difference of amount, under deposit work.

Proper booking of the expenditure may be done against the deposit works.

Right of way for proposed line shall be provided by applicant.

If any litigation arises, it will be the liability of applicant.

The applicant will apply separately to RRVPNL for new 33 KV bay at 400/220/132/33 KV GSS Bhadla.

This bears the approval of Hon'ble Managing Director, Jodhpur Discom, Jodhpur, vide note sheet no. 2739 dated 12.03.21.

incl: - Case file

for information & nA.
Encl: Case file Ata Coll

Superintending Engineer (PP&M) Jodhpur Discom, Jodhpur

opy submitted/forwarded to the following for information and necessary action.

1. The Superintending Engineer (O&M), JdVVNL, Jaisalmer.

2. The Executive Engineer (O&V), JdVVNL Pokaran.

3. The Assistant Engineer (O&M), JdVVNL Nachana.

4. The Accounts Officer (O&M), JdVVNL, Jaisalmer.

No 3193 DT 30 03 2021

OPY Josnarded to the SE(olar) Idvort, Superintending Engineer (PP&M)

Idisalmen for information & nece search Jodhpur Discom, Jodhpur

action

Encl:- Case file+ Tech restricts

कपसाटर उपमाक्ता द्वारा उपलब्ध कराया जायेगा।

4. रकम व "एल" फार्म पहले जमा कराने पर प्राथमिकता दी जावेगी।

विद्यत संबंध ARMOURED CABLE के द्वारा दिया जायेगा।

जे. वि. वि. नि: लि.