

**Field inspection notes of Shri. S. Shantharam I.F.S., District Forest Officer, Kumram Bheem-Asifabad on Diversion area of 6.6766 Ha of Forest land in Kaghaznagar Division for Erection of 33 KV Interlinking line from 33/11 KV SS PENCHIKALPET to Loadpally 33 KV Cut point in PENCHIKALPET (M) of Kaghaznagar Division of Kumrambheem Asifabad District in favour Divisional Engineer, Operation, M/s TSNPDCL, Kaghaznagar**

\*\*\*\*\*

Today on 18.05.2022 inspected the proposed Diversion area of 6.6766 Ha of Forest land in Kaghaznagar Division for Erection of 33 KV Interlinking line from 33/11 KV SS PENCHIKALPET to Loadpally 33 KV Cut point in PENCHIKALPET (M) of Kaghaznagar Division of Kumrambheem Asifabad District in favour Divisional Engineer, Operation, M/s TSNPDCL, Kaghaznagar (User Agency) along with concerned staff. As per the field verification of the proposed diversion area, the details of which are as follows.

Sl. No.	Range	Section	Beat	Compt No	Name of the RF	Proposed diversion area as per DGPS authentication by the Prl.C.C.F. Hyd			Proposed area for Diversion as per field verification			Remarks
						Length in Mts	Width in Mts	Area in Ha	Length in Mts	Width in Mts	Area in Ha	
1	Penchikalpet	Penchikalpet	Bombaiguda	155	Kadamba	4451.08	15.00	6.6766	641.08	15	0.9616	Corridor of Kawal Tiger Reserve
2	Penchikalpet	Penchikalpet	Bombaiguda	Kadamba Ext-VI	Kadamba Ext-VI				2230	15	3.3450	Corridor of Kawal Tiger Reserve
3	Penchikalpet	Loadpally	Loadpally	Bejjur Ext-VII	Bejjur Ext-VII				850	15	1.2750	Corridor of Kawal Tiger Reserve
4	Penchikalpet	Loadpally	Loadpally	236	Bejjur				730	15	1.0950	Corridor of Kawal Tiger Reserve
		Total				4451.08		6.6766	4451.08		6.6766	

The aforesaid proposed diversion area is passing through Kadamba, Kadamba Ext-VI, Bejjur Ext – VII and Bejjur RF in PENCHIKALPET Range of Kaghaznagar Division and the total length is **4451.08 meters** with a width of **15.00 meters** which is amounting to the total area, required for diversion in Kaghaznagar division is **6.6766 ha**.



In the proposed diversion area, no unique tree is found, no protected archaeological / heritage site / defense establishment or any other important monument is found in the area. The proposed diversion area of 6.6766 ha is falling in “Corridor of Kawal Tiger Reserve” through compartment number 155 of Kadamba, Kadamba Ext-VI, Bejjur Ext – VII and Compt No. 236 of Bejjur RF of PENCHIKALPET Range. The proposed diversion of forest area for Non forestry purpose. The area is having different type of vegetations, which is having 0.1 to 0.3 Density. The tree growth having in the proposed diversion forest area.

**1566889/2022/ADMIN SECTION-PCCF**

The area proposed for diversion is barest minimum and unavoidable without alternatives for the project. Thus, Diversion area of 6.6766 Ha of Forest land in Kaghaznagar Division for Erection of 33 KV Interlinking line from 33/11 KV SS Panchikalpet to Loadpally 33 KV Cut point in Panchikalpet (M) of Kaghaznagar Division of Kumrambheem Asifabad District in favour Divisional Engineer, Operation, M/s TSNPDCL, Kaghaznagar is recommended based on the field conditions and future impact. Regarding violations in the Forest Conservation Act, 1980, there is no violation in the proposed site of the project.

Hence it is recommended for considering the proposal, if the following conditions (A) is agreed by the user agency.

- (A) The proposed diversion area is falling "Corridor of Kawal Tiger Reserve, which is noticed with Tiger Movement in this area and also wildlife movement as this area". Therefore transmission lines in forest areas should be insulated (Aerial Bunched Cable) instead of overhead lines, due to protection of Wildlife.

(B)

  
District Forest Officer  
Kumram Bheem Asifabad  
Komaram Bheem  
(Asifabad)